

East Syracuse Elementary

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	lead	actions taken	actions planned
Main Office sink	<1 ppb		
8	14 ppb		
Nurse's Office	<1 ppb		
Nurse's Hall DF tall	<1 ppb		
Nurse's Hall DF shrt.	<1 ppb		
Custodial breakrm.	1.2 ppb		
Café Hallway DF tall	<1 ppb		
Café Hall DF short	<1 ppb		
Kitchen hand sink	1.3 ppb		
Kitchen sink-North	1.2 ppb		
Kitchen sink-South	1.6 ppb		
Faculty Room	<1 ppb		
Library Work Room	<1 ppb		
202 DF	<1 ppb		
204 DF	<1 ppb		
206 DF	<1 ppb		
208 DF	<1 ppb		
205 DF	<1 ppb		
210 DF	<1ppb		
211 DF	<1 ppb		
209 DF	<1 ppb		
207 DF	<1 ppb		
3 DF	<1 ppb		
2 DF	<1 ppb		
1 DF	<1 ppb		
K wing DF tall	<1 ppb		
K wing DF short	<1 ppb		
102 DF	<1 ppb		
104 DF	<1 ppb		
106 DF	<1 ppb		
108 DF	<1 ppb		
110 DF	<1 ppb		
112 DF	<1ppb		
107 DF	<1 ppb		
105 DF	<1 ppb		
103 DF	<1 ppb		

101 DF	<1 ppb
--------	--------

samples taken 9/22/16

Nurse bathroom	<1 ppb
----------------	--------

Boys' gym bathroom	<1 ppb
--------------------	--------

Girls' gym bathroom	<1 ppb
---------------------	--------

Rm. 1 sink	<1ppb
------------	-------

Rm. 1 bathroom	<1 ppb
----------------	--------

Rm. 2 sink	<1 ppb
------------	--------

Rm. 3 sink	<1 ppb
------------	--------

Rm. 3 bathroom	<1 ppb
----------------	--------

101 sink	<1 ppb
----------	--------

101 bathroom	<1 ppb
--------------	--------

103 sink	1.4 ppb
----------	---------

103 BR	<1 ppb
--------	--------

105 sink	<1 ppb
----------	--------

105 BR	<1 ppb
--------	--------

107 sink	<1 ppb
----------	--------

107 BR	<1 ppb
--------	--------

112 sink	<1 ppb
----------	--------

112 BR	2.8 ppb
--------	---------

110 sink	<1 ppb
----------	--------

110 BR	<1 ppb
--------	--------

108 sink	<1 ppb
----------	--------

108 BR	1.1 ppb
--------	---------

106 sink	1.2 ppb
----------	---------

106 BR	<1 ppb
--------	--------

104 sink	<1 ppb
----------	--------

104 BR	<1 ppb
--------	--------

102 sink	<1 ppb
----------	--------

102 BR	2.2 ppb
--------	---------

102 sink #1	1.1 ppb
-------------	---------

102 sink #2	2.2 ppb
-------------	---------

102 sink #3	1.9 ppb
-------------	---------

102 sink #4	1.1 ppb
-------------	---------

205 sink	<1 ppb
----------	--------

205 BR	2.2 ppb
--------	---------

207 sink	3.2 ppb
----------	---------

207 BR	<1 ppb
--------	--------

209 sink	<1 ppb
----------	--------

209 BR	<1 ppb
--------	--------

211 sink	1.2 ppb
211 BR	1.4 ppb
210 sink	<1 ppb
210 BR	<1 ppb
208 sink	1.4 ppb
208 BR	1.2 ppb
206 sink	<1 ppb
206 BR	<1 ppb
204 sink	<1 ppb
204 BR	<1 ppb
202 sink	1.1 ppb
202 BR	<1 ppb
Girls' 2nd fl. BR sink #1	<1 ppb
Girls' 2nd fl. BR sink #2	<1 ppb
Girls' 2nd fl. BR sink #3	<1 ppb
Boys' 2nd fl. BR sink#1	1.1 ppb
Boys' 2nd fl. BR sink#2	<1 ppb
Boys' 2nd fl. BR sink#3	1.1 ppb
216 sink	1.2 ppb
Cafeteria sink	<1 ppb

Fremont Elementary

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	lead	actions taken	actions planned
Kitchen sink	12 ppb		
Café DF L	2.2 ppb		
Café DF R	2.6 ppb		
Main Hall DF tall	<1 ppb		
Main Hall Dfshort	<1 ppb		
Library sink	1.3 ppb		
Main Office sink	1.2 ppb		
106 sink	<1 ppb		
110 DF	<1 ppb		
112 DF	<1 ppb		
111 DF	<1 ppb		
11 DF	12 ppb		
12 DF	6.9 ppb		
13 DF	7.4 ppb		
14 DF	4.8 ppb		

15 DF	12 ppb
16 DF	11 ppb
17 DF	7 ppb
18 DF	9.7 ppb
19 DF	13 ppb
20 DF	3 ppb
21 DF	8.6 ppb
22 DF	3.9 ppb
23 DF	3.7 ppb
24 DF	1.8 ppb
25 DF	4.3 ppb
26 DF	2.3 ppb
27 DF	3.4 ppb
28 sink	<1 ppb
29 sink	9.9 ppb
samples taken on 9/21/16	
boys' BR sink #1	2.1 ppb
boys' BR sink #2	1.6 ppb
girls' BR sink #1	1.9 ppb
girls' BR sink #2	3.1 ppb
girls' BR sink #3	2.6 ppb
Library sink	<1 ppb
Nurse's exam sink	1.3 ppb
Nurse's BR sink	<1 ppb
Nurse's MW sink	1.2 ppb
108 sink	1.5 ppb
110 sink	<1 ppb
111 sink	<1 ppb
112 sink	<1 ppb
2nd fl boys' sink #1	5.7 ppb
2nd fl boys' sink #2	2.6 ppb
2nd fl boys' sink #3	2.2 ppb
20 sink	6.1 ppb
21 sink	11 ppb
22 sink	2.0 ppb
23 sink	5.3 ppb
24 sink	1.6 ppb
25 sink	3.6 ppb
26 sink	5.4 ppb
27 sink	2.8 ppb

28 sink	<1 ppb
29 sink	9.8 ppb
2nd fl girls' sink #1	2.5 ppb
2nd fl girls' sink #2	1.7 ppb
2nd fl girls' sink #3	2.0 ppb
10 sink	8.6 ppb
10 BR	4.6 ppb
11 sink	1.1 ppb
11 BR	5.1 ppb
12 sink	5.0 ppb
12 BR	2.8 ppb
13 sink	7.6 ppb
13 BR	4.2 ppb
14 sink	3.7 ppb
14 BR	7.8 ppb
15 sink	7.7 ppb
15 BR	6.8 ppb
16 sink	7.2 ppb
16 BR	2.4 ppb
17 sink	6.1 ppb
17 BR	2.3 ppb
18 sink	6.2 ppb
18 BR	4.7 ppb
19 sink	7.8 ppb
19 BR	3.9 ppb

Minoa Elementary

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	lead	actions taken	actions planned	10/28/16 samples
Kitchen Women's	2.3 ppb			
Kitchen	9.5 ppb			
Café DF left	<1 ppb			
Café DF right	<1 ppb			
Hallway DF tall	<1 ppb			
Hallway DF short	<1 ppb			
Teachers' b brkrm.	2.7 ppb			
21 DF	14 ppb			
22 DF	17 ppb*	water shut off	replaced local plumbing, re-sampled and sent to lab.	14 ppb
23 DF	11 ppb			

24 DF	16 ppb*	water shut off	replaced local plumbing, re-sampled and sent to lab.	16 ppb*
25 DF	15 ppb	water shut off		
26 DF	11 ppb			
27 DF	6.5 ppb			
28 DF	16 ppb*	water shut off	replaced local plumbing, re-sampled and sent to lab.	16 ppb*
5 DF	18 ppb*	water shut off, replaced local plumbing	replaced bubbler, re-sampled and sent to lab	
7 DF	18 ppb*	water shut off	replaced local plumbing, re-sampled and sent to lab.	9.9 ppb
8 DF	11 ppb			
9 DF	12 ppb			
10 DF	15 ppb	water shut off, installed in-line filter		
11 DF	11 ppb			
19 DF	9.7 ppb			
18 DF	8.3 ppb			
17 DF	12 ppb			
16 DF	46 ppb*	shut off, plumb. rem. & repl., bubbler repl, filter installed, re-sampled and sent to lab.	re-sample & test.	
15 DF	10 ppb			
14 DF	9.9 ppb			
13 DF	46 ppb*	shut off, plumb. rem. & repl., bubbler repl, filter installed, re-sampled and sent to lab.	re-sample & test.	
Nurse's sink faucet	<1 ppb			
Nurse's bath	3.8 ppb			
3 DF	12 ppb			
2 DF	8.5 ppb			
1 DF	1.7 ppb			
20 DF	9 ppb			
samples taken 1/13/17, results received 1/20/17				
Boys' BR sink #1	3.8 ppb			
Boys' BR sink #2	1.8 ppb			
Girls' BR sink #1	2.2 ppb			
Girls' BR sink #2	1.1 ppb			
Girls' BR sink #3	1.5 ppb			
13 bathroom	2.4 ppb			
14 sink	2.4 ppb			
14 bathroom	2.6 ppb			
15 bathroom	1.9 ppb			
16 bathroom	13 ppb			
17 sink	5.3 ppb			
17 bathroom	1.7 ppb			
18 sink	4.2 ppb			
18 bathroom	3.4 ppb			
19 sink	4.8 ppb			

19 bathroom	3.1 ppb	
20 sink	9.5 ppb	
20 bathroom	3.0 ppb	
A-1 sink	1.1 ppb	
A-1 bathroom	2.3 ppb	
2 sink	7.4 ppb	
2 bathroom	3.2 ppb	
Nurse's hand sink	<1 ppb	
Nurse's exam sink	22 ppb*	shut down, plumbing replacement underway
Nurse's BR sink	2.9 ppb	
3 sink	9.9 ppb	
3 bathroom	3.3 ppb	
4 right sink	4.4 ppb	
4 left sink	5.2 ppb	
4 bathroom	4.5 ppb	
Girls' 5th gr BR sink1	2.1 ppb	
Girls' 5th gr BR sink2	1.1 ppb	
Girls' 5th gr BR sink3	1.9 ppb	
Boys' 5th gr BR sink1	2.1 ppb	
Boys' 5th gr BR sink2	1.5 ppb	
Boys' 5th gr BR sink3	1.5 ppb	
6 sink	12 ppb	
8 sink	4.6 ppb	
9 sink	5.9 ppb	
10 sink	3.9 ppb	
11 sink	12 ppb	
21 sink	7.2 ppb	
21 bathroom	4.6 ppb	
22 bathroom	4.6 ppb	
23 sink	8.8 ppb	
23 bathroom	2.5 ppb	
24 bathroom	2.5 ppb	
25 bathroom	3.2 ppb	
26 sink	4.7 ppb	
26 bathroom	4.3 ppb	
27 sink	6.7 ppb	
27 bathroom	3.0 ppb	
28 bathroom	4.1 ppb	
samples taken 2/9/17, results received 2/14/17		
13 sink	<1 ppb	

Park Hill Pre-K

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	lead	actions taken	actions planned
Kitchen sink	15 ppb	installed in-line filter	
Cafeteria DF left	1.3 ppb		
Cafeteria DF right	9.5 ppb		
305 sink	8.4 ppb		
Nurse's front sink	4.2 ppb		
Nurse's back sink	9.3 ppb		
Basement DF	<1 ppb		
6 sink	8.1 ppb		
Basement sink	5.2 ppb		
104 sink	<1 ppb		
1st Floor Hallway DF	2.1 ppb		
103A sink	1.7 ppb		
208 sink	3.4 ppb		
2nd Floor DF	5.1 ppb		
2nd fl. womens' R	3.9 ppb		
301 DF	39 ppb*	water shut off perm. decommissioned	
301 sink	3.6 ppb		
301 bathroom	12 ppb		
302 DF	22 ppb*	water shut off perm. decommissioned	
302 sink	2.6 ppb		
302 bathroom	6.9 ppb		
303 DF	15 ppb	water shut off perm. decommissioned	
303 sink	6.1 ppb		
303 bathroom	6 ppb		
304 bathroom	7.7 ppb		
305 bathroom	5 ppb		
306 DF	83 ppb*	water shut off perm. decommissioned	
306 sink	5.1 ppb		
306 bathroom	5.2 ppb		
307 sink	7.5 ppb		
307 bathroom	6.8 ppb		
308 DF	67 ppb*	water shut off perm. decommissioned	
308 sink	9.4 ppb		
308 bathroom	5.4 ppb		
309 DF	34 ppb*	water shut off perm. decommissioned	

309 sink	4.4 ppb
309 bathroom	8.9 ppb
1st fl. Boys' bath #1	1.8 ppb
1st fl. Boys' bath #2	1.3 ppb
103A bathroom	6.1 ppb
1st fl. Girls' bath #1	4.5 ppb
1st fl. Girls' bath #2	5.4 ppb
2nd fl. Girls' bath #1	<1 ppb

Woodland Elementary

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	lead	actions taken	actions planned
Main Office sink	<1 ppb		
Nurse's Hallway DF	<1 ppb		
Kitchen sink #1	3.9 ppb		
Kitchen sink #2	<1 ppb		
Nurse's Office	<1 ppb		
Library breakroom	4.2 ppb		
Cust. Hallway DF	3.1 ppb		
108 Custodial sink	2.6 ppb		
DF near Rm. 133	<1 ppb		
137 sink #1	2.5 ppb		
137 sink #2	<1 ppb		
Hallway DF tall	<1 ppb		
Hallway DF short	<1 ppb		
Teachers' breakrm.	4.1 ppb		
118 DF	7.9 ppb		
119 DF	5.1 ppb		
Hallway DF near 118	4.4 ppb		
120 DF	6.2 ppb		
121 DF	3.5 ppb		
122 DF	3.9 ppb		
123 DF	3.6 ppb		
124 DF	3.7 ppb		
125 DF	4.7 ppb		
127 DF	6.9 ppb		
128 DF	6.6 ppb		
Boys' bath near cust.	<1 ppb		
Girls' bath near cust	<1 ppb		
Nurse's bath	<1 ppb		

Rm. 128 bath	2.2 ppb
Rm. 128 sink	6.5 ppb
Rm. 127 bath	5.6 ppb
Rm. 127 sink	1.1 ppb
Rm. 126 sink	6.3 ppb
Rm. 114 fountain	4.1 ppb
Rm. 114 sink	2.3 ppb
Rm. 115 sink	1.2 ppb
Rm. 118 sink	3.4 ppb
Rm. 118 bath	<1 ppb
Rm. 119 sink	1.5 ppb
Rm. 119 bath	1.4 ppb
Rm. 121 sink	4.7 ppb
Rm. 121 bath	1.6 ppb
Rm. 120 sink	3.7 ppb
Rm. 120 bath	1ppb
Rm. 122 sink	13 ppb
Rm. 122 bath	2 ppb
Rm. 123 sink	4.5 ppb
Rm. 123 bath	1.8 ppb
Rm. 124 sink	7.7 ppb
Rm. 124 bath	2.1 ppb
Rm. 125 sink	4 ppb
Rm. 125 bath	1.2 ppb
Rm. 144 sink	1 ppb
Rm. 145 sink	<1 ppb
Rm. 142 sink	2.3 ppb
Rm. 143 sink	1.4 ppb
Rm. 154 boys' bath 1	<1 ppb
Rm. 154 boys' bath 2	<1 ppb
Rm. 154 boys' bath 3	<1 ppb
Rm. 154 boys' bath 4	<1 ppb
Rm. 139 sink	2.2 ppb
Rm. 140 sink	3.5 ppb
Rm. 136 bathroom	1.1 ppb
Rm. 135 sink	3.6 ppb
Rm. 132 sink	1.2 ppb
Rm. 149 girls' bath 1	<1 ppb
Rm. 149 girls' bath 2	<1 ppb
Rm. 149 girls' sink#3	<1 ppb

Rm. 149 girls' sink#4	<1 ppb
Rm. 133 sink	3.7 ppb
Rm. 130 sink	<1 ppb
Rmf. 131 sink	5.6 ppb
Rm. 146 sink #1	7.2 ppb
Rm. 146 sink #2	3.1 ppb

High School

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	lead	actions taken	actions planned
Kitchen sink #2	2.6 ppb		
Kitchen sink-center	2.3 ppb		
Kitchen sink #1	3.8 ppb		
Kitchen soup spigot	4.5 ppb		
DF near lg. café L	<1 ppb		
Df near lg. café R	<1 ppb		
D wing DF left	<1 ppb		
D wing DF right	<1 ppb		
D11 sink	13 ppb		
D16 sink	36 ppb*	plumbing modification	re-test
D14 prep room sink	1.2 ppb		
D20 prep sink	5.5 ppb		
E wing DF nr lg caf L	13 ppb		
E wing DF nr lg caf R	11 ppb		
E11 sink South	<1 ppb		
E11 sink North	1.1 ppb		
E7 sink	<1 ppb		
E6 sink	<1 ppb		
DF in hall near E22 L	<1 ppb		
DF in hall near E22 R	<1 ppb		
E22 left	<1ppb		
E22 right	<1 ppb		
Library	2 ppb		
Nurse NS right	<1 ppb		
Nurse NS left	<1 ppb		
Staff Room KC	<1 ppb		
Office WC left 27-A	<1 ppb		
Office WC left 28-A	<1ppb		
DF near art room	8.8 ppb		

C wing teachers' bkr	1.5 ppb	
E20 sink #1	<1 ppb	
E20 sink #2	1.9 ppb	
E20 sink #3	<1 ppb	
E20 sink #4	<1 ppb	
C3	<1 ppb	
C3 prep sink #1	<1 ppb	
C3 prep sink #2	<1 ppb	
DF near G19	<1 ppb	
DF near G20 tall	<1 ppb	
DF near G20 short	<1 ppb	
G9 sink	<1 ppb	
G13 (Teachers' Rm.)	1.1 ppb	
DF near G14	<1 ppb	
G14 sink	<1 ppb	
Atrium Band area DF	<1 ppb	
G3 Band Room DF	<1 ppb	
Main Hallway DF L	1.7 ppb	
DF near B13 R	1.5 ppb	
DF near B13	4.8 ppb	
B1 Faculty Room	<1 ppb	
DF near B36	9.9 ppb	
B2 Faculty Room	<1 ppb	
DF near B43	<1 ppb	
DF near B9 tall	<1 ppb	
DF near B9 short	<1 ppb	
DF near wgt rm tall	<1 ppb	
DF near wgt rm shrt	<1 ppb	
DF near AD tall	<1 ppb	
DF near AD short	<1 ppb	
DF near men's F7	5.9 ppb	
Girls' PE Office sink	<1 ppb	
Athl Trainer Off. sink	<1 ppb	
Custodial Office	1.3 ppb	
Concession Stand	3.4 ppb	
Baseball Field	8.6 ppb	
samples taken 10/18/16		
D2 sink #1	40 ppb*	posted non-potable
D2 sink #2	22 ppb*	posted non-potable
D2 sink #3	24 ppb*	posted non-potable

D2 sink #4	22 ppb*	posted non-potable
D2 sink #5	14 ppb	
D2 prep room	13 ppb	
D1 sink #1	21 ppb*	posted non-potable
D1 sink #2	12 ppb	
D1 sink #3	18 ppb*	posted non-potable
D1 sink #4	26 ppb*	posted non-potable
D1 sink #5	23 ppb*	posted non-potable
D1 prep room	4.2 ppb	
D4 sink #1	31 ppb*	posted non-potable
D4 sink #2	22 ppb*	posted non-potable
D4 sink #3	23 ppb*	posted non-potable
D4 sink #4	20 ppb*	posted non-potable
D4 sink #5	15 ppb	posted non-potable
D4 prep room	14 ppb	
D5 sink #1	6.5 ppb	
D5 sink #2	16 ppb*	posted non-potable
D5 sink #3	16 ppb*	posted non-potable
D5 sink #4	10 ppb	
D5 sink #5	21 ppb*	posted non-potable
D8 sink #1	11 ppb	
D8 sink #2	28 ppb*	posted non-potable
D8 sink #3	6.9 ppb	
D8 sink #4	16 ppb*	posted non-potable
D8 prep room	17 ppb*	posted non-potable
D9 sink #1	19 ppb*	posted non-potable
D9 sink #2	19 ppb*	posted non-potable
D9 sink #3	19 ppb*	posted non-potable
D9 sink #4	17 ppb*	posted non-potable
D9 sink #5	17 ppb*	posted non-potable
D9 prep room	12 ppb	
D10 sink #1	24 ppb*	posted non-potable
D10 sink #2	20 ppb*	posted non-potable
D10 sink #3	20 ppb*	posted non-potable
D10 sink #4	25 ppb*	posted non-potable
D10 sink #5	15 ppb	posted non-potable
D10 prep room	12 ppb	
D11 sink #1	19 ppb*	posted non-potable
D11 sink #2	17 ppb*	posted non-potable
D11 sink #3	17 ppb*	posted non-potable

D11 sink #4	27 ppb*	posted non-potable
D11 sink #5	18 ppb*	posted non-potable
D11 prep room	13 ppb	
D16 sink #2	16 ppb*	posted non-potable
D16 sink #3	19 ppb*	posted non-potable
D17 prep room	14 ppb	
D17 sink #1	50 ppb*	posted non-potable
D17 sink #2	26 ppb*	posted non-potable
D17 sink #3	18 ppb*	posted non-potable
D18 prep room	19 ppb*	posted non-potable
D18 sink #1	10 ppb	
D18 sink #2	14 ppb	
D18 sink #3	18 ppb*	posted non-potable
D19 prep room	33 ppb*	posted non-potable
D19 sink #1	13 ppb	
D19 sink #2	26 ppb*	posted non-potable
D19 sink #3	18 ppb*	posted non-potable
D20 prep room	22 ppb*	posted non-potable
D20 sink #2	6.4 ppb	
D20 sink #3	16 ppb*	posted non-potable
Unisex BR near D20	11 ppb	
New DF in D wing	<1 ppb	
New DF bottle flr.	<1 ppb	
Old DF (left)	<1 ppb	
Girls' BR nr lg café 1	<1 ppb	
Girls' BR nr lg café 2	<1 ppb	
Girls' BR nr lg café 3	<1 ppb	
Girls' BR nr lg café 4	1.6 ppb	
Boys' BR nr lg café 1	<1 ppb	
Boys' BR nr lg café 2	<1 ppb	
Boys' BR nr lg café 3	1.0 ppb	
Boys' BR nr lg café 4	2.0 ppb	
Bathroom near C2	<1 ppb	
C9 sink	<1 ppb	
C3 hand sink	<1 ppb	
Sink room sink #1 L	<1 ppb	
Sink room sink #2 R	1.1 ppb	
Sink room hand sink	11 ppb	
C10 sink L	<1 ppb	
C10 sink R	<1 ppb	

C11 sink	2.6 ppb
C6 sink L	<1 ppb
C6 sink R	<1 ppb
C6 hand sink	<1 ppb
C7 sink	4.2 ppb
C8 bathroom	<1 ppb
Boys' BR near G20 #1	<1 ppb
Boys' BR near G20 #2	<1 ppb
Boys' BR near G20 #3	<1 ppb
Boys' BR near G20 #4	<1 ppb
Boys' BR near G20 #5	<1 ppb
Girls' BR near G20 #1	<1 ppb
Girls' BR near G20 #2	<1 ppb
Girls' BR near G20 #4	<1 ppb
Girls' BR near G20 #5	<1 ppb
G9 sink	<1 ppb
G3 drinking fountain	<1 ppb
G13 sink	<1 ppb
G14 sink	<1 ppb
Girls' E1 BR sink #1	<1 ppb
Girls' E1 BR sink #2	<1 ppb
Girls' E1 BR sink #3	<1 ppb
Boys' E1 BR sink #1	10 ppb
Boys' E1 BR sink #2	<1 ppb
Boys' E1 BR sink #3	1.8 ppb
B12 work room sink	<1 ppb
B8 faculty room	<1 ppb
B9 sink	<1 ppb
Girls' B9 BR sink #1	<1 ppb
Girls' B9 BR sink #2	<1 ppb
Girls' B9 BR sink #3	<1 ppb
Girls' B9 BR sink #4	<1 ppb
Girls' B9 BR sink #5	<1 ppb
Boys' B9 BR sink #1	<1 ppb
Boys' B9 BR sink #2	<1 ppb
Boys' B9 BR sink #3	<1 ppb
Boys' B9 BR sink #4	<1 ppb
Boys' B9 BR sink #5	1.3 ppb
Trainer's room sink	<1 ppb

additional samples taken 10/18/16, results rec'd 1/11/2017

Kitchen ice maker	<1 ppb
Custodial break rm.	<1 ppb
Team room 2, sink 1	<1 ppb
Team room 2, sink 2	<1 ppb
Team room 1, sink 1	<1 ppb
Team room 1, sink 2	<1 ppb
Girls' locker, sink 1	<1 ppb
Girls' locker, sink 2	<1 ppb
Girls' locker, sink 3	<1 ppb
Girls' locker, sink 4	<1 ppb
Women's PE sink	<1 ppb
Women's PE BR	<1 ppb
Girls' BR nr F2, sink 1	<1 ppb
Girls' BR nr F2, sink 2	1.5 ppb
Girls' BR nr F2, sink 3	5.3 ppb
Girls' BR nr F2, sink 4	2.7 ppb
Girls' BR nr F2, sink 5	1.6 ppb
Boys' BR nr F2, sink1	5.2 ppb
Boys' BR nr F2, sink2	2.7 ppb
Boys' BR nr F2, sink3	3.5 ppb
Boys' BR nr F2, sink4	7.0 ppb
Boys' BR nr F2, sink5	4.8 ppb
Athl Trainer-ice mch	<1 ppb
Athl Trainer-sink	<1 ppb
Men's PE sink	<1 ppb
Men's PE bathroom	<1 ppb
Boys' locker, sink #1	8.6 ppb
Boys' locker, sink #2	3.5 ppb
Boys' locker, sink #3	<1 ppb
Boys' locker, sink #4	3.7 ppb
Boys' team 1, sink1	3.5 ppb
Boys' team 1, sink2	<1 ppb
Boys' team 2, sink 1	<1 ppb
Boys' team 2, sink 2	<1 ppb
Boys' lg gym BR, sk1	3.1 ppb
Boys' lg gym BR, sk2	1.8 ppb
Girls' lg gym BR, sk1	2.7 ppb
Girls' lg gym BR, sk2	8.2 ppb
Girls' lg gym BR, sk3	8.8 ppb
Nurse's ice machine	<1 ppb

Nurse's bathroom	<1 ppb
------------------	--------

Pine Grove Middle School

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

sample date - 10/5/2016

Room	lead	actions taken
------	------	---------------

Kitchen sink left	3.1 ppb	
-------------------	---------	--

Kitchen sink right	5 ppb	
--------------------	-------	--

Kitchen wash sink	<1 ppb	
-------------------	--------	--

DF near C109 short	<1 ppb	
--------------------	--------	--

DF near C109 tall	<1 ppb	
-------------------	--------	--

Rm. 105	<1 ppb	
---------	--------	--

Rm. 104	13 ppb	
---------	--------	--

100 sink #1	<1 ppb	
-------------	--------	--

100 sink #2	<1 ppb	
-------------	--------	--

100 sink #3	<1 ppb	
-------------	--------	--

100 sink #4	<1 ppb	
-------------	--------	--

100 hand sink	9.4 ppb	
---------------	---------	--

101 sink	6.7 ppb	
----------	---------	--

Rm. 102	3.4 ppb	
---------	---------	--

103 bathroom	<1 ppb	
--------------	--------	--

Men BR near 103 right	<1 ppb	
-----------------------	--------	--

Men BR near 103 left	<1 ppb	
----------------------	--------	--

109 staff room	3.5 ppb	
----------------	---------	--

DF near B103 short	<1 ppb	
--------------------	--------	--

DF near B103 tall	<1 ppb	
-------------------	--------	--

Boys' BR near B102 #1	<1 ppb	
-----------------------	--------	--

Boys' BR near B102 #2	<1 ppb	
-----------------------	--------	--

Boys' BR near B102 #3	1 ppb	
-----------------------	-------	--

Women BR left	<1 ppb	
---------------	--------	--

Women BR right	<1 ppb	
----------------	--------	--

Girls' BR near B102 #1	<1 ppb	
------------------------	--------	--

Girls' BR near B102 #2	<1 ppb	
------------------------	--------	--

Girls' BR near B102 #3	8.9 ppb	
------------------------	---------	--

B102	5.9 ppb	
------	---------	--

A113	5.8 ppb	
------	---------	--

A100	3.2 ppb	
------	---------	--

DF near Rm. 100 short	<1 ppb	
-----------------------	--------	--

DF near Rm. 100 tall	<1 ppb	
----------------------	--------	--

Girls' BR sink tall	1.2 ppb	
---------------------	---------	--

Girls' BR sink short	1.2 ppb	
----------------------	---------	--

Boys' BR sink tall	3.4 ppb
Boys' BR sink short	2.1 ppb
DF foyer tall	<1 ppb
DF foyer short	<1 ppb
Main Office sink	<1 ppb
Girls' BR near E102 tall	<1 ppb
Girls' BR near E102 sht	<1 ppb
Boys' BR near E102 sht	<1 ppb
Boys' BR near E102 tall	<1 ppb
DF near gym tall	<1 ppb
DF near gym short	<1 ppb
DF near gym w/bottle	<1 ppb
D103 DF	3.0 ppb
D103 sink	1.6 ppb
D102 sink	1.2 ppb
BR across from D108	<1 ppb
Girls' locker room BR	<1 ppb
Girls' LR BR sink short	<1 ppb
Girl's LR BR sink tall	<1 ppb
DF near E117 tall	<1 ppb
DF near E117 short	<1 ppb
DF bottle filler nr E117	<1 ppb
E116 Coach BR	<1 ppb
E116 Boys' LR sink #1	<1 ppb
E116 Boys' LR sink #2	<1 ppb
E116 Boys' LR sink #3	<1 ppb
E120 Coach BR	1.1 ppb
E109A sink	<1 ppb
E107 sink #1	<1 ppb
E107 sink #2	5.1 ppb
E107 Nurse bathroom	<1 ppb
E108 bathroom	<1 ppb
Boys' BR sink #1 212B	<1 ppb
Boys' BR sink #2 212B	<1 ppb
Girls' BR sink #1 212B	<1 ppb
Girl's BR sink #2 212B	<1 ppb
Library Office	3.8 ppb
2nd fl DF tall Area 7	1.3 ppb
2nd fl DF short Area 7	<1 ppb
F200 sink #1	<1 ppb

F200 sink #2	<1 ppb					
F202 sink #1	2.3 ppb					
F202 sink #2	2.2 ppb					
F211 sink #1	<1 ppb					
F211 sink #2	<1 ppb					
F213 sink #1	1.1 ppb					
F213 sink #2	1.1 ppb					
G200 sink #1	43 ppb*	shut down outlet, waiting for lead-free replacement faucet	faucet replaced	6.7 ppb	12/2/16 sample	returned to service
G200 sink #2	42 ppb*	shut down outlet, waiting for lead-free replacement faucet	faucet replaced	25 ppb*	10/18/16 sample	filter TBI
G200 sink #3	49 ppb*	shut down outlet, waiting for lead-free replacement faucet	faucet replaced	24 ppb*	10/18/16 sample	filter TBI
G200 snk #4	60 ppb*	shut down outlet, waiting for lead-free replacement faucet	faucet replaced	14 ppb	10/18/16 sample	returned to service
G201 sink #1	23 ppb*	shut down outlet, waiting for lead-free replacement faucet	faucet replaced	22 ppb*	10/18/16 sample	filter TBI
G201 sink #2	22 ppb*	shut down outlet, waiting for lead-free replacement faucet	faucet replaced	5.5 ppb	10/18/16 sample	returned to service
G201 sink #3	18 ppb*	shut down outlet, waiting for lead-free replacement faucet	faucet replaced	27 ppb*	10/18/16 sample	filter TBI
G201 sink #4	32 ppb*	shut down outlet, waiting for lead-free replacement faucet	faucet replaced	24 ppb*	10/18/16 sample	filter TBI
G202 sink #1	20 ppb*	shut down outlet, waiting for lead-free replacement faucet	faucet replaced	13 ppb	10/18/16 sample	returned to service
G202 sink #2	17 ppb*	shut down outlet, waiting for lead-free replacement faucet	faucet replaced	9.7 ppb	10/18/16 sample	returned to service
G202 sink #3	18 ppb*	shut down outlet, waiting for lead-free replacement faucet	faucet replaced	10 ppb	10/18/16 sample	returned to service
G202 sink #4	22 ppb*	shut down outlet, waiting for lead-free replacement faucet	faucet replaced	16 ppb*	10/18/16 sample	filter TBI
G203 Girls' BR sink #1	1.1 ppb					
G203 Girls' BR sink #2	<1 ppb					
G203 Girls' BR sink #3	1.3 ppb					
G203 Boys' BR sink #1	1.5 ppb					
G203 Boys' BR sink #2	<1 ppb					
G203 Boys' BR sink #3	1.6 ppb					
G203 DF tall	<1 ppb					
G203 DF short	<1 ppb					
G203 Women BR snk 1	1.3 ppb					
G203 Women BR snk 2	<1 ppb					
G204 Men BR sink #1	<1 ppb					
G204 Men BR sink #2	<1 ppb					
G204 sink #1	<1 ppb					
G201 DF tall	1.3 ppb					
G201 DF short	<1 ppb					
H200 sink #1	1.8 ppb					
H200 sink #2	<1 ppb					
H202 sink #1	<1 ppb					
H202 sink #2	<1 ppb					
H211 sink #1	3.2 ppb					
H211 sink #2	<1 ppb					

H213 sink #1	1 ppb
H213 sink #2	<1 ppb
samples taken 10/28/16	
Serving line sink	2.8 ppb
BR 120a	1.4 ppb
BR 120b	<1 ppb
A101 sink #1	1.6 ppb
A101 sink #2	<1 ppb
A103	7.2 ppb
A109	2.3 ppb
A112	<1 ppb
E109a ice machine	<1 ppb
C100 ice machine	<1 ppb
samples taken 12/2/16	
E109a sink	2.7 ppb
E109a ice machine	<1 ppb