

## East Syracuse Elementary

\* indicates that source reading exceeds permissible level (greater than 15 ppb)

Room	lead	actions taken	Results Received	
Nurse's Hall DF shrt.	<1.0			
Nurse's office	<1.0			
nurse bathroom	<1.0			
main office sink	<1.0			
k wing df tall	<1.0			
k wing df short	<1.0			
1df	<1.0			
2df	<1.0			
3df	<1.0			
102df	<1.0			
104df	<1.0			
106df	<1.0			
202df	<1.0			
204df	<1.0			
206df	<1.0			
205df	<1.0			
208df	<1.0			
210df	<1.0			
207df	<1.0			
209df	<1.0			
211df	<1.0			
	8	5.7		
library work room	43*	out of service, parts to be replaced	1.1 Ppb 4-1-20	Returned to Service
faculty room	<1.0			
cafe hallway df tall	<1.0			
cafe hallway df short	<1.0			
kitchen sink north	<1.0			
kitchen sink south right	<1.0			
nurses hall df tall	<1.0			
bys gym bathroom	<1.0			
rm1 sink	<1.0			
rm2 sink	<1.0			
rm3 bathroom	<1.0			
rm3 sink	<1.0			
rm 101 d fountain	<1.0			
rm103 sink	<1.0			
rm 103 df	1.1			
rm 103 bathroom	<1.0			
rm105 sink	<1.0			

rm105 bathroom	<1.0		
rm 105 df	<1.0		
rm 106 sink	2.1		
rm 107 sink	<1.0		
rm 107 df	<1.0		
rmo108df	<1.0		
rm 108 sink	<1.0		
rm 110 sink	<1.0		
rm110 df	<1.0		
rm112sink	<1.0		
rm112 df	<1.0		
rm 112 bathroom	<1.0		
rm 4sink	1.3		
101 sink XXXXXXXX			
102 bathroom	1.1		
102 sink	<1.0		
202 sink	<1.0		
207 sink	<1.0		
108 bathroom	2		
204 sink	<1.0		
205 sink	<1.0		
206 bathroom	3.4		
206 sink	<1.0		
207 bathroom	<1.0		
202 bathroom	<1.0		
209 bathroom	<1.0		
209 sink	<1.0		
210 sink	1.1		
211 sink	1.3		
rm 216 sink	1.9		
Cafeteria sink	<1.0		
208 sink	<1.0		
210 bathroom	<1.0		
104 sink	<1.0		
106 bathroom	<1.0		
girls 2nd floor br sink # 1	<1.0		
girls 2nd floor br sink # 2	<1.0		
girls 2nd floor br sink # 3	<1.0		
boys 2nd floor br left sink	<1.0		
boys 2nd floor br center sink	<1.0		
boys 2nd floor br rt sink	<1.0		