

East Syracuse Elementary

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

| Room | lead | actions taken | actions planned |
|------------------------------|-------------|----------------------|------------------------|
| Main Office sink | <1 ppb | | |
| 8 | 14 ppb | | |
| Nurse's Office | <1 ppb | | |
| Nurse's Hall DF tall | <1 ppb | | |
| Nurse's Hall DF shrt. | <1 ppb | | |
| Custodial breakrm. | 1.2 ppb | | |
| Café Hallway DF tall | <1 ppb | | |
| Café Hall DF short | <1 ppb | | |
| Kitchen hand sink | 1.3 ppb | | |
| Kitchen sink-North | 1.2 ppb | | |
| Kitchen sink-South | 1.6 ppb | | |
| Faculty Room | <1 ppb | | |
| Library Work Room | <1 ppb | | |
| 202 DF | <1 ppb | | |
| 204 DF | <1 ppb | | |
| 206 DF | <1 ppb | | |
| 208 DF | <1 ppb | | |
| 205 DF | <1 ppb | | |
| 210 DF | <1ppb | | |
| 211 DF | <1 ppb | | |
| 209 DF | <1 ppb | | |
| 207 DF | <1 ppb | | |
| 3 DF | <1 ppb | | |
| 2 DF | <1 ppb | | |
| 1 DF | <1 ppb | | |
| K wing DF tall | <1 ppb | | |
| K wing DF short | <1 ppb | | |
| 102 DF | <1 ppb | | |
| 104 DF | <1 ppb | | |
| 106 DF | <1 ppb | | |
| 108 DF | <1 ppb | | |
| 110 DF | <1 ppb | | |
| 112 DF | <1ppb | | |
| 107 DF | <1 ppb | | |
| 105 DF | <1 ppb | | |
| 103 DF | <1 ppb | | |
| 101 DF | <1 ppb | | |
| samples taken 9/22/16 | | | |

| | |
|---------------------|---------|
| Nurse bathroom | <1 ppb |
| Boys' gym bathroom | <1 ppb |
| Girls' gym bathroom | <1 ppb |
| Rm. 1 sink | <1ppb |
| Rm. 1 bathroom | <1 ppb |
| Rm. 2 sink | <1 ppb |
| Rm. 3 sink | <1 ppb |
| Rm. 3 bathroom | <1 ppb |
| 101 sink | <1 ppb |
| 101 bathroom | <1 ppb |
| 103 sink | 1.4 ppb |
| 103 BR | <1 ppb |
| 105 sink | <1 ppb |
| 105 BR | <1 ppb |
| 107 sink | <1 ppb |
| 107 BR | <1 ppb |
| 112 sink | <1 ppb |
| 112 BR | 2.8 ppb |
| 110 sink | <1 ppb |
| 110 BR | <1 ppb |
| 108 sink | <1 ppb |
| 108 BR | 1.1 ppb |
| 106 sink | 1.2 ppb |
| 106 BR | <1 ppb |
| 104 sink | <1 ppb |
| 104 BR | <1 ppb |
| 102 sink | <1 ppb |
| 102 BR | 2.2 ppb |
| 102 sink #1 | 1.1 ppb |
| 102 sink #2 | 2.2 ppb |
| 102 sink #3 | 1.9 ppb |
| 102 sink #4 | 1.1 ppb |
| 205 sink | <1 ppb |
| 205 BR | 2.2 ppb |
| 207 sink | 3.2 ppb |
| 207 BR | <1 ppb |
| 209 sink | <1 ppb |
| 209 BR | <1 ppb |
| 211 sink | 1.2 ppb |
| 211 BR | 1.4 ppb |
| 210 sink | <1 ppb |

| | |
|---------------------------|---------|
| 210 BR | <1 ppb |
| 208 sink | 1.4 ppb |
| 208 BR | 1.2 ppb |
| 206 sink | <1 ppb |
| 206 BR | <1 ppb |
| 204 sink | <1 ppb |
| 204 BR | <1 ppb |
| 202 sink | 1.1 ppb |
| 202 BR | <1 ppb |
| Girls' 2nd fl. BR sink #1 | <1 ppb |
| Girls' 2nd fl. BR sink #2 | <1 ppb |
| Girls' 2nd fl. BR sink #3 | <1 ppb |
| Boys' 2nd fl. BR sink#1 | 1.1 ppb |
| Boys' 2nd fl. BR sink#2 | <1 ppb |
| Boys' 2nd fl. BR sink#3 | 1.1 ppb |
| 216 sink | 1.2 ppb |
| Cafeteria sink | <1 ppb |

Fremont Elementary

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

| Room | lead | actions taken | actions planned |
|-------------------|---------|---------------|-----------------|
| Kitchen sink | 12 ppb | | |
| Café DF L | 2.2 ppb | | |
| Café DF R | 2.6 ppb | | |
| Main Hall DF tall | <1 ppb | | |
| Main Hall Dfshort | <1 ppb | | |
| Library sink | 1.3 ppb | | |
| Main Office sink | 1.2 ppb | | |
| 106 sink | <1 ppb | | |
| 110 DF | <1 ppb | | |
| 112 DF | <1 ppb | | |
| 111 DF | <1 ppb | | |
| 11 DF | 12 ppb | | |
| 12 DF | 6.9 ppb | | |
| 13 DF | 7.4 ppb | | |
| 14 DF | 4.8 ppb | | |
| 15 DF | 12 ppb | | |
| 16 DF | 11 ppb | | |
| 17 DF | 7 ppb | | |
| 18 DF | 9.7 ppb | | |

| | |
|---------------------------------|---------|
| 19 DF | 13 ppb |
| 20 DF | 3 ppb |
| 21 DF | 8.6 ppb |
| 22 DF | 3.9 ppb |
| 23 DF | 3.7 ppb |
| 24 DF | 1.8 ppb |
| 25 DF | 4.3 ppb |
| 26 DF | 2.3 ppb |
| 27 DF | 3.4 ppb |
| 28 sink | <1 ppb |
| 29 sink | 9.9 ppb |
| samples taken on 9/21/16 | |
| boys' BR sink #1 | 2.1 ppb |
| boys' BR sink #2 | 1.6 ppb |
| girls' BR sink #1 | 1.9 ppb |
| girls' BR sink #2 | 3.1 ppb |
| girls' BR sink #3 | 2.6 ppb |
| Library sink | <1 ppb |
| Nurse's exam sink | 1.3 ppb |
| Nurse's BR sink | <1 ppb |
| Nurse's MW sink | 1.2 ppb |
| 108 sink | 1.5 ppb |
| 110 sink | <1 ppb |
| 111 sink | <1 ppb |
| 112 sink | <1 ppb |
| 2nd fl boys' sink #1 | 5.7 ppb |
| 2nd fl boys' sink #2 | 2.6 ppb |
| 2nd fl boys' sink #3 | 2.2 ppb |
| 20 sink | 6.1 ppb |
| 21 sink | 11 ppb |
| 22 sink | 2.0 ppb |
| 23 sink | 5.3 ppb |
| 24 sink | 1.6 ppb |
| 25 sink | 3.6 ppb |
| 26 sink | 5.4 ppb |
| 27 sink | 2.8 ppb |
| 28 sink | <1 ppb |
| 29 sink | 9.8 ppb |
| 2nd fl girls' sink #1 | 2.5 ppb |
| 2nd fl girls' sink #2 | 1.7 ppb |
| 2nd fl girls' sink #3 | 2.0 ppb |

| | |
|---------|---------|
| 10 sink | 8.6 ppb |
| 10 BR | 4.6 ppb |
| 11 sink | 1.1 ppb |
| 11 BR | 5.1 ppb |
| 12 sink | 5.0 ppb |
| 12 BR | 2.8 ppb |
| 13 sink | 7.6 ppb |
| 13 BR | 4.2 ppb |
| 14 sink | 3.7 ppb |
| 14 BR | 7.8 ppb |
| 15 sink | 7.7 ppb |
| 15 BR | 6.8 ppb |
| 16 sink | 7.2 ppb |
| 16 BR | 2.4 ppb |
| 17 sink | 6.1 ppb |
| 17 BR | 2.3 ppb |
| 18 sink | 6.2 ppb |
| 18 BR | 4.7 ppb |
| 19 sink | 7.8 ppb |
| 19 BR | 3.9 ppb |

Minoa Elementary * indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

| Room | lead | actions taken | actions planned | 10/28/16 samples |
|---------------------|---------|-----------------------------------------|------------------------------------------------------|--------------------|
| Kitchen Women's | 2.3 ppb | | | |
| Kitchen | 9.5 ppb | | | |
| Café DF left | <1 ppb | | | |
| Café DF right | <1 ppb | | | |
| Hallway DF tall | <1 ppb | | | |
| Hallway DF short | <1 ppb | | | |
| Teachers' br brkrm. | 2.7 ppb | | | |
| 21 DF | 14 ppb | | | |
| 22 DF | 17 ppb* | water shut off | replaced local plumbing, re-sampled and sent to lab. | 14 ppb |
| 23 DF | 11 ppb | | | |
| 24 DF | 16 ppb* | water shut off | replaced local plumbing, re-sampled and sent to lab. | 16 ppb* ***** |
| 25 DF | 15 ppb | water shut off | | ***** |
| 26 DF | 11 ppb | | | |
| 27 DF | 6.5 ppb | | | |
| 28 DF | 16 ppb* | water shut off | replaced local plumbing, re-samplec | 16 ppb* ***** |
| 5 DF | 18 ppb* | water shut off, replaced local plumbing | replaced bubbler, re-sampled and sent to lab | ***** sink is good |

| | | | |
|--------------------------------------------------------|---------|---------------------------------------------------------------------------------|--------------------------------------------|
| 7 DF | 18 ppb* | water shut off | replaced local plumbing, re-sample 9.9 ppb |
| 8 DF | 11 ppb | | |
| 9 DF | 12 ppb | | |
| 10 DF | 15 ppb | water shut off, installed in-line filter | ***** sink is good |
| 11 DF | 11 ppb | | |
| 19 DF | 9.7 ppb | | |
| 18 DF | 8.3 ppb | | |
| 17 DF | 12 ppb | | |
| 16 DF | 46 ppb* | shut off, plumb. rem. & repl., bubbler repl, filter installed re-sample & test. | ***** sink is good |
| 15 DF | 10 ppb | | |
| 14 DF | 9.9 ppb | | |
| 13 DF | 46 ppb* | shut off, plumb. rem. & repl., bubbler repl, filter installed re-sample & test. | ***** sink is good |
| Nurse's sink faucet | <1 ppb | | |
| Nurse's bath | 3.8 ppb | | |
| 3 DF | 12 ppb | | |
| 2 DF | 8.5 ppb | | |
| 1 DF | 1.7 ppb | | |
| 20 DF | 9 ppb | | |
| samples taken 1/13/17, results received 1/20/17 | | | |
| Boys' BR sink #1 | 3.8 ppb | | |
| Boys' BR sink #2 | 1.8 ppb | | |
| Girls' BR sink #1 | 2.2 ppb | | |
| Girls' BR sink #2 | 1.1 ppb | | |
| Girls' BR sink #3 | 1.5 ppb | | |
| 13 bathroom | 2.4 ppb | | |
| 14 sink | 2.4 ppb | | |
| 14 bathroom | 2.6 ppb | | |
| 15 bathroom | 1.9 ppb | | |
| 16 bathroom | 13 ppb | | |
| 17 sink | 5.3 ppb | | |
| 17 bathroom | 1.7 ppb | | |
| 18 sink | 4.2 ppb | | |
| 18 bathroom | 3.4 ppb | | |
| 19 sink | 4.8 ppb | | |
| 19 bathroom | 3.1 ppb | | |
| 20 sink | 9.5 ppb | | |
| 20 bathroom | 3.0 ppb | | |
| A-1 sink | 1.1 ppb | | |
| A-1 bathroom | 2.3 ppb | | |
| 2 sink | 7.4 ppb | | |

| | | |
|-------------------------------------------------------|----------|------------------------------------------|
| 2 bathroom | 3.2 ppb | |
| Nurse's hand sink | <1 ppb | |
| Nurse's exam sink | 22 ppb* | shut down, plumbing replacement underway |
| Nurse's BR sink | 2.9 ppb | |
| 3 sink | 9.9 ppb | |
| 3 bathroom | 3.3 ppb | |
| 4 right sink | 4.4 ppb | |
| 4 left sink | 5.2 ppb | |
| 4 bathroom | 4.5 ppb | |
| Girls' 5th gr BR sink1 | 2.1 ppb | |
| Girls' 5th gr BR sink2 | 1.1 ppb | |
| Girls' 5th gr BR sink3 | 1.9 ppb | |
| Boys' 5th gr BR sink1 | 2.1 ppb | |
| Boys' 5th gr BR sink2 | 1.5 ppb | |
| Boys' 5th gr BR sink3 | 1.5 ppb | |
| 6 sink | 12 ppb | |
| 8 sink | 4.6 ppb | |
| 9 sink | 5.9 ppb | |
| 10 sink | 3.9 ppb | |
| 11 sink | 12 ppb | |
| 21 sink | 7.2 ppb | |
| 21 bathroom | 4.6 ppb | |
| 22 bathroom | 4.6 ppb | |
| 23 sink | 8.8 ppb | |
| 23 bathroom | 2.5 ppb | |
| 24 bathroom | 2.5 ppb | |
| 25 bathroom | 3.2 ppb | |
| 26 sink | 4.7 ppb | |
| 26 bathroom | 4.3 ppb | |
| 27 sink | 6.7 ppb | |
| 27 bathroom | 3.0 ppb | |
| 28 bathroom | 4.1 ppb | |
| samples taken 2/9/17, results received 2/14/17 | | |
| 13 sink | <1 ppb | |
| samples taken 3/9/17, results received 3/28/17 | | |
| 5 sink | 8.2 ppb | opened on 3/28/17 |
| 16 sink | 4.5 ppb | opened on 3/28/17 |
| 24 sink | 72 ppb* | remains shut off w/DF |
| 25 sink | 110 ppb* | remains shut off w/DF |
| 28 sink | 110 ppb* | remains shut off w/DF |
| | | |

Park Hill Pre-K

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

| Room | lead | actions taken | actions planned |
|-----------------------|-------------|--------------------------|------------------------|
| Kitchen sink | 15 ppb | installed in-line filter | |
| Cafeteria DF left | 1.3 ppb | | |
| Cafeteria DF right | 9.5 ppb | | |
| 305 sink | 8.4 ppb | | |
| Nurse's front sink | 4.2 ppb | | |
| Nurse's back sink | 9.3 ppb | | |
| Basement DF | <1 ppb | | |
| 6 sink | 8.1 ppb | | |
| Basement sink | 5.2 ppb | | |
| 104 sink | <1 ppb | | |
| 1st Floor Hallway DF | 2.1 ppb | | |
| 103A sink | 1.7 ppb | | |
| 208 sink | 3.4 ppb | | |
| 2nd Floor DF | 5.1 ppb | | |
| 2nd fl. womens' R | 3.9 ppb | | |
| 301 DF | 39 ppb* | water shut off | perm. decommissioned |
| 301 sink | 3.6 ppb | | |
| 301 bathroom | 12 ppb | | |
| 302 DF | 22 ppb* | water shut off | perm. decommissioned |
| 302 sink | 2.6 ppb | | |
| 302 bathroom | 6.9 ppb | | |
| 303 DF | 15 ppb | water shut off | perm. decommissioned |
| 303 sink | 6.1 ppb | | |
| 303 bathroom | 6 ppb | | |
| 304 bathroom | 7.7 ppb | | |
| 305 bathroom | 5 ppb | | |
| 306 DF | 83 ppb* | water shut off | perm. decommissioned |
| 306 sink | 5.1 ppb | | |
| 306 bathroom | 5.2 ppb | | |
| 307 sink | 7.5 ppb | | |
| 307 bathroom | 6.8 ppb | | |
| 308 DF | 67 ppb* | water shut off | perm. decommissioned |
| 308 sink | 9.4 ppb | | |
| 308 bathroom | 5.4 ppb | | |
| 309 DF | 34 ppb* | water shut off | perm. decommissioned |
| 309 sink | 4.4 ppb | | |
| 309 bathroom | 8.9 ppb | | |
| 1st fl. Boys' bath #1 | 1.8 ppb | | |

| | | | |
|----------------------------|-------------|---------------------------------------------------------------------------|------------------------|
| 1st fl. Boys' bath #2 | 1.3 ppb | | |
| 103A bathroom | 6.1 ppb | | |
| 1st fl. Girls' bath #1 | 4.5 ppb | | |
| 1st fl. Girls' bath #2 | 5.4 ppb | | |
| 2nd fl. Girls' bath #1 | <1 ppb | | |
| Woodland Elementary | | * indicates that source reading exceeds 9/6/16 permissible level (15 ppb) | |
| Room | lead | actions taken | actions planned |
| Main Office sink | <1 ppb | | |
| Nurse's Hallway DF | <1 ppb | | |
| Kitchen sink #1 | 3.9 ppb | | |
| Kitchen sink #2 | <1 ppb | | |
| Nurse's Office | <1 ppb | | |
| Library breakroom | 4.2 ppb | | |
| Cust. Hallway DF | 3.1 ppb | | |
| 108 Custodial sink | 2.6 ppb | | |
| DF near Rm. 133 | <1 ppb | | |
| 137 sink #1 | 2.5 ppb | | |
| 137 sink #2 | <1 ppb | | |
| Hallway DF tall | <1 ppb | | |
| Hallway DF short | <1 ppb | | |
| Teachers' breakrm. | 4.1 ppb | | |
| 118 DF | 7.9 ppb | | |
| 119 DF | 5.1 ppb | | |
| Hallway DF near 118 | 4.4 ppb | | |
| 120 DF | 6.2 ppb | | |
| 121 DF | 3.5 ppb | | |
| 122 DF | 3.9 ppb | | |
| 123 DF | 3.6 ppb | | |
| 124 DF | 3.7 ppb | | |
| 125 DF | 4.7 ppb | | |
| 127 DF | 6.9 ppb | | |
| 128 DF | 6.6 ppb | | |
| Boys' bath near cust. | <1 ppb | | |
| Girls' bath near cust | <1 ppb | | |
| Nurse's bath | <1 ppb | | |
| Rm. 128 bath | 2.2 ppb | | |
| Rm. 128 sink | 6.5 ppb | | |
| Rm. 127 bath | 5.6 ppb | | |
| Rm. 127 sink | 1.1 ppb | | |

| | |
|-----------------------|---------|
| Rm. 126 sink | 6.3 ppb |
| Rm. 114 fountain | 4.1 ppb |
| Rm. 114 sink | 2.3 ppb |
| Rm. 115 sink | 1.2 ppb |
| Rm. 118 sink | 3.4 ppb |
| Rm. 118 bath | <1 ppb |
| Rm. 119 sink | 1.5 ppb |
| Rm. 119 bath | 1.4 ppb |
| Rm. 121 sink | 4.7 ppb |
| Rm. 121 bath | 1.6 ppb |
| Rm. 120 sink | 3.7 ppb |
| Rm. 120 bath | 1ppb |
| Rm. 122 sink | 13 ppb |
| Rm. 122 bath | 2 ppb |
| Rm. 123 sink | 4.5 ppb |
| Rm. 123 bath | 1.8 ppb |
| Rm. 124 sink | 7.7 ppb |
| Rm. 124 bath | 2.1 ppb |
| Rm. 125 sink | 4 ppb |
| Rm. 125 bath | 1.2 ppb |
| Rm. 144 sink | 1 ppb |
| Rm. 145 sink | <1 ppb |
| Rm. 142 sink | 2.3 ppb |
| Rm. 143 sink | 1.4 ppb |
| Rm. 154 boys' bath 1 | <1 ppb |
| Rm. 154 boys' bath 2 | <1 ppb |
| Rm. 154 boys' bath 3 | <1 ppb |
| Rm. 154 boys' bath 4 | <1 ppb |
| Rm. 139 sink | 2.2 ppb |
| Rm. 140 sink | 3.5 ppb |
| Rm. 136 bathroom | 1.1 ppb |
| Rm. 135 sink | 3.6 ppb |
| Rm. 132 sink | 1.2 ppb |
| Rm. 149 girls' bath 1 | <1 ppb |
| Rm. 149 girls' bath 2 | <1 ppb |
| Rm. 149 girls' sink#3 | <1 ppb |
| Rm. 149 girls' sink#4 | <1 ppb |
| Rm. 133 sink | 3.7 ppb |
| Rm. 130 sink | <1 ppb |
| Rmf. 131 sink | 5.6 ppb |
| Rm. 146 sink #1 | 7.2 ppb |

| | | | |
|----------------------------------------------------------------------------------------------|-------------|-----------------------|------------------------|
| Rm. 146 sink #2 | 3.1 ppb | | |
| High School * indicates that source reading exceeds 9/6/16 permissible level (15 ppb) | | | |
| Room | lead | actions taken | actions planned |
| Kitchen sink #2 | 2.6 ppb | | |
| Kitchen sink-center | 2.3 ppb | | |
| Kitchen sink #1 | 3.8 ppb | | |
| Kitchen soup spigot | 4.5 ppb | | |
| DF near lg. café L | <1 ppb | | |
| Df near lg. café R | <1 ppb | | |
| D wing DF left | <1 ppb | | |
| D wing DF right | <1 ppb | | |
| D11 sink | 13 ppb | | |
| D16 sink | 36 ppb* | plumbing modification | re-test |
| D14 prep room sink | 1.2 ppb | | |
| D20 prep sink | 5.5 ppb | | |
| E wing DF nr lg caf L | 13 ppb | | |
| E wing DF nr lg caf R | 11 ppb | | |
| E11 sink South | <1 ppb | | |
| E11 sink North | 1.1 ppb | | |
| E7 sink | <1 ppb | | |
| E6 sink | <1 ppb | | |
| DF in hall near E22 L | <1 ppb | | |
| DF in hall near E22 R | <1 ppb | | |
| E22 left | <1ppb | | |
| E22 right | <1 ppb | | |
| Library | 2 ppb | | |
| Nurse NS right | <1 ppb | | |
| Nurse NS left | <1 ppb | | |
| Staff Room KC | <1 ppb | | |
| Office WC left 27-A | <1 ppb | | |
| Office WC left 28-A | <1ppb | | |
| DF near art room | 8.8 ppb | | |
| C wing teachers' bkr | 1.5 ppb | | |
| E20 sink #1 | <1 ppb | | |
| E20 sink #2 | 1.9 ppb | | |
| E20 sink #3 | <1 ppb | | |
| E20 sink #4 | <1 ppb | | |
| C3 | <1 ppb | | |

| | | |
|-------------------------------|---------|--------------------|
| C3 prep sink #1 | <1 ppb | |
| C3 prep sink #2 | <1 ppb | |
| DF near G19 | <1 ppb | |
| DF near G20 tall | <1 ppb | |
| DF near G20 short | <1 ppb | |
| G9 sink | <1 ppb | |
| G13 (Teachers' Rm.) | 1.1 ppb | |
| DF near G14 | <1 ppb | |
| G14 sink | <1 ppb | |
| Atrium Band area DF | <1 ppb | |
| G3 Band Room DF | <1 ppb | |
| Main Hallway DF L | 1.7 ppb | |
| DF near B13 R | 1.5 ppb | |
| DF near B13 | 4.8 ppb | |
| B1 Faculty Room | <1 ppb | |
| DF near B36 | 9.9 ppb | |
| B2 Faculty Room | <1 ppb | |
| DF near B43 | <1 ppb | |
| DF near B9 tall | <1 ppb | |
| DF near B9 short | <1 ppb | |
| DF near wgt rm tall | <1 ppb | |
| DF near wgt rm shrt | <1 ppb | |
| DF near AD tall | <1 ppb | |
| DF near AD short | <1 ppb | |
| DF near men's F7 | 5.9 ppb | |
| Girls' PE Office sink | <1 ppb | |
| Athl Trainer Off. sink | <1 ppb | |
| Custodial Office | 1.3 ppb | |
| Concession Stand | 3.4 ppb | |
| Baseball Field | 8.6 ppb | |
| samples taken 10/18/16 | | |
| D2 sink #1 | 40 ppb* | posted non-potable |
| D2 sink #2 | 22 ppb* | posted non-potable |
| D2 sink #3 | 24 ppb* | posted non-potable |
| D2 sink #4 | 22 ppb* | posted non-potable |
| D2 sink #5 | 14 ppb | |
| D2 prep room | 13 ppb | |
| D1 sink #1 | 21 ppb* | posted non-potable |
| D1 sink #2 | 12 ppb | |
| D1 sink #3 | 18 ppb* | posted non-potable |
| D1 sink #4 | 26 ppb* | posted non-potable |

| | | |
|---------------|---------|--------------------|
| D1 sink #5 | 23 ppb* | posted non-potable |
| D1 prep room | 4.2 ppb | |
| D4 sink #1 | 31 ppb* | posted non-potable |
| D4 sink #2 | 22 ppb* | posted non-potable |
| D4 sink #3 | 23 ppb* | posted non-potable |
| D4 sink #4 | 20 ppb* | posted non-potable |
| D4 sink #5 | 15 ppb | posted non-potable |
| D4 prep room | 14 ppb | |
| D5 sink #1 | 6.5 ppb | |
| D5 sink #2 | 16 ppb* | posted non-potable |
| D5 sink #3 | 16 ppb* | posted non-potable |
| D5 sink #4 | 10 ppb | |
| D5 sink #5 | 21 ppb* | posted non-potable |
| D8 sink #1 | 11 ppb | |
| D8 sink #2 | 28 ppb* | posted non-potable |
| D8 sink #3 | 6.9 ppb | |
| D8 sink #4 | 16 ppb* | posted non-potable |
| D8 prep room | 17 ppb* | posted non-potable |
| D9 sink #1 | 19 ppb* | posted non-potable |
| D9 sink #2 | 19 ppb* | posted non-potable |
| D9 sink #3 | 19 ppb* | posted non-potable |
| D9 sink #4 | 17 ppb* | posted non-potable |
| D9 sink #5 | 17 ppb* | posted non-potable |
| D9 prep room | 12 ppb | |
| D10 sink #1 | 24 ppb* | posted non-potable |
| D10 sink #2 | 20 ppb* | posted non-potable |
| D10 sink #3 | 20 ppb* | posted non-potable |
| D10 sink #4 | 25 ppb* | posted non-potable |
| D10 sink #5 | 15 ppb | posted non-potable |
| D10 prep room | 12 ppb | |
| D11 sink #1 | 19 ppb* | posted non-potable |
| D11 sink #2 | 17 ppb* | posted non-potable |
| D11 sink #3 | 17 ppb* | posted non-potable |
| D11 sink #4 | 27 ppb* | posted non-potable |
| D11 sink #5 | 18 ppb* | posted non-potable |
| D11 prep room | 13 ppb | |
| D16 sink #2 | 16 ppb* | posted non-potable |
| D16 sink #3 | 19 ppb* | posted non-potable |
| D17 prep room | 14 ppb | |
| D17 sink #1 | 50 ppb* | posted non-potable |
| D17 sink #2 | 26 ppb* | posted non-potable |

| | | |
|------------------------|---------|--------------------|
| D17 sink #3 | 18 ppb* | posted non-potable |
| D18 prep room | 19 ppb* | posted non-potable |
| D18 sink #1 | 10 ppb | |
| D18 sink #2 | 14 ppb | |
| D18 sink #3 | 18 ppb* | posted non-potable |
| D19 prep room | 33 ppb* | posted non-potable |
| D19 sink #1 | 13 ppb | |
| D19 sink #2 | 26 ppb* | posted non-potable |
| D19 sink #3 | 18 ppb* | posted non-potable |
| D20 prep room | 22 ppb* | posted non-potable |
| D20 sink #2 | 6.4 ppb | |
| D20 sink #3 | 16 ppb* | posted non-potable |
| Unisex BR near D20 | 11 ppb | |
| New DF in D wing | <1 ppb | |
| New DF bottle flr. | <1 ppb | |
| Old DF (left) | <1 ppb | |
| Girls' BR nr lg café 1 | <1 ppb | |
| Girls' BR nr lg café 2 | <1 ppb | |
| Girls' BR nr lg café 3 | <1 ppb | |
| Girls' BR nr lg café 4 | 1.6 ppb | |
| Boys' BR nr lg café 1 | <1 ppb | |
| Boys' BR nr lg café 2 | <1 ppb | |
| Boys' BR nr lg café 3 | 1.0 ppb | |
| Boys' BR nr lg café 4 | 2.0 ppb | |
| Bathroom near C2 | <1 ppb | |
| C9 sink | <1 ppb | |
| C3 hand sink | <1 ppb | |
| Sink room sink #1 L | <1 ppb | |
| Sink room sink #2 R | 1.1 ppb | |
| Sink room hand sink | 11 ppb | |
| C10 sink L | <1 ppb | |
| C10 sink R | <1 ppb | |
| C11 sink | 2.6 ppb | |
| C6 sink L | <1 ppb | |
| C6 sink R | <1 ppb | |
| C6 hand sink | <1 ppb | |
| C7 sink | 4.2 ppb | |
| C8 bathroom | <1 ppb | |
| Boys' BR near G20 #1 | <1 ppb | |
| Boys' BR near G20 #2 | <1 ppb | |
| Boys' BR near G20 #3 | <1 ppb | |

| | |
|-------------------------------------------------------------------|---------|
| Boys' BR near G20 #4 | <1 ppb |
| Boys' BR near G20 #5 | <1 ppb |
| Girls' BR near G20 #1 | <1 ppb |
| Girls' BR near G20 #2 | <1 ppb |
| Girls' BR near G20 #4 | <1 ppb |
| Girls' BR near G20 #5 | <1 ppb |
| G9 sink | <1 ppb |
| G3 drinking fountain | <1 ppb |
| G13 sink | <1 ppb |
| G14 sink | <1 ppb |
| Girls' E1 BR sink #1 | <1 ppb |
| Girls' E1 BR sink #2 | <1 ppb |
| Girls' E1 BR sink #3 | <1 ppb |
| Boys' E1 BR sink #1 | 10 ppb |
| Boys' E1 BR sink #2 | <1 ppb |
| Boys' E1 BR sink #3 | 1.8 ppb |
| B12 work room sink | <1 ppb |
| B8 faculty room | <1 ppb |
| B9 sink | <1 ppb |
| Girls' B9 BR sink #1 | <1 ppb |
| Girls' B9 BR sink #2 | <1 ppb |
| Girls' B9 BR sink #3 | <1 ppb |
| Girls' B9 BR sink #4 | <1 ppb |
| Girls' B9 BR sink #5 | <1 ppb |
| Boys' B9 BR sink #1 | <1 ppb |
| Boys' B9 BR sink #2 | <1 ppb |
| Boys' B9 BR sink #3 | <1 ppb |
| Boys' B9 BR sink #4 | <1 ppb |
| Boys' B9 BR sink #5 | 1.3 ppb |
| Trainer's room sink | <1 ppb |
| additional samples taken 10/18/16, results rec'd 1/11/2017 | |
| Kitchen ice maker | <1 ppb |
| Custodial break rm. | <1 ppb |
| Team room 2, sink 1 | <1 ppb |
| Team room 2, sink 2 | <1 ppb |
| Team room 1, sink 1 | <1 ppb |
| Team room 1, sink 2 | <1 ppb |
| Girls' locker, sink 1 | <1 ppb |
| Girls' locker, sink 2 | <1 ppb |
| Girls' locker, sink 3 | <1 ppb |
| Girls' locker, sink 4 | <1 ppb |

| | |
|-------------------------|---------|
| Women's PE sink | <1 ppb |
| Women's PE BR | <1 ppb |
| Girls' BR nr F2, sink 1 | <1 ppb |
| Girls' BR nr F2, sink 2 | 1.5 ppb |
| Girls' BR nr F2, sink 3 | 5.3 ppb |
| Girls' BR nr F2, sink 4 | 2.7 ppb |
| Girls' BR nr F2, sink 5 | 1.6 ppb |
| Boys' BR nr F2, sink1 | 5.2 ppb |
| Boys' BR nr F2, sink2 | 2.7 ppb |
| Boys' BR nr F2, sink3 | 3.5 ppb |
| Boys' BR nr F2, sink4 | 7.0 ppb |
| Boys' BR nr F2, sink5 | 4.8 ppb |
| Athl Trainer-ice mch | <1 ppb |
| Athl Trainer-sink | <1 ppb |
| Men's PE sink | <1 ppb |
| Men's PE bathroom | <1 ppb |
| Boys' locker, sink #1 | 8.6 ppb |
| Boys' locker, sink #2 | 3.5 ppb |
| Boys' locker, sink #3 | <1 ppb |
| Boys' locker, sink #4 | 3.7 ppb |
| Boys' team 1, sink1 | 3.5 ppb |
| Boys' team 1, sink2 | <1 ppb |
| Boys' team 2, sink 1 | <1 ppb |
| Boys' team 2, sink 2 | <1 ppb |
| Boys' lg gym BR, sk1 | 3.1 ppb |
| Boys' lg gym BR, sk2 | 1.8 ppb |
| Girls' lg gym BR, sk1 | 2.7 ppb |
| Girls' lg gym BR, sk2 | 8.2 ppb |
| Girls' lg gym BR, sk3 | 8.8 ppb |
| Nurse's ice machine | <1 ppb |
| Nurse's bathroom | <1 ppb |

Pine Grove Middle School * indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

sample date - 10/5/2016

| Room | lead | actions taken |
|--------------------|---------|---------------|
| Kitchen sink left | 3.1 ppb | |
| Kitchen sink right | 5 ppb | |
| Kitchen wash sink | <1 ppb | |
| DF near C109 short | <1 ppb | |
| DF near C109 tall | <1 ppb | |
| Rm. 105 | <1 ppb | |

| | |
|--------------------------|---------|
| Rm. 104 | 13 ppb |
| 100 sink #1 | <1 ppb |
| 100 sink #2 | <1 ppb |
| 100 sink #3 | <1 ppb |
| 100 sink #4 | <1 ppb |
| 100 hand sink | 9.4 ppb |
| 101 sink | 6.7 ppb |
| Rm. 102 | 3.4 ppb |
| 103 bathroom | <1 ppb |
| Men BR near 103 right | <1 ppb |
| Men BR near 103 left | <1 ppb |
| 109 staff room | 3.5 ppb |
| DF near B103 short | <1 ppb |
| DF near B103 tall | <1 ppb |
| Boys' BR near B102 #1 | <1 ppb |
| Boys' BR near B102 #2 | <1 ppb |
| Boys' BR near B102 #3 | 1 ppb |
| Women BR left | <1 ppb |
| Women BR right | <1 ppb |
| Girls' BR near B102 #1 | <1 ppb |
| Girls' BR near B102 #2 | <1 ppb |
| Girls' BR near B102 #3 | 8.9 ppb |
| B102 | 5.9 ppb |
| A113 | 5.8 ppb |
| A100 | 3.2 ppb |
| DF near Rm. 100 short | <1 ppb |
| DF near Rm. 100 tall | <1 ppb |
| Girls' BR sink tall | 1.2 ppb |
| Girls' BR sink short | 1.2 ppb |
| Boys' BR sink tall | 3.4 ppb |
| Boys' BR sink short | 2.1 ppb |
| DF foyer tall | <1 ppb |
| DF foyer short | <1 ppb |
| Main Office sink | <1 ppb |
| Girls' BR near E102 tall | <1 ppb |
| Girls' BR near E102 sht | <1 ppb |
| Boys' BR near E102 sht | <1 ppb |
| Boys' BR near E102 tall | <1 ppb |
| DF near gym tall | <1 ppb |
| DF near gym short | <1 ppb |
| DF near gym w/bottle | <1 ppb |

| | | | | | | | | | |
|--------------------------|---------|-------------------------------------------|-----------------|---------|-----------------|---------------------|--------|----------|--|
| D103 DF | 3.0 ppb | | | | | | | | |
| D103 sink | 1.6 ppb | | | | | | | | |
| D102 sink | 1.2 ppb | | | | | | | | |
| BR across from D108 | <1 ppb | | | | | | | | |
| Girls' locker room BR | <1 ppb | | | | | | | | |
| Girls' LR BR sink short | <1 ppb | | | | | | | | |
| Girls' LR BR sink tall | <1 ppb | | | | | | | | |
| DF near E117 tall | <1 ppb | | | | | | | | |
| DF near E117 short | <1 ppb | | | | | | | | |
| DF bottle filler nr E117 | <1 ppb | | | | | | | | |
| E116 Coach BR | <1 ppb | | | | | | | | |
| E116 Boys' LR sink #1 | <1 ppb | | | | | | | | |
| E116 Boys' LR sink #2 | <1 ppb | | | | | | | | |
| E116 Boys' LR sink #3 | <1 ppb | | | | | | | | |
| E120 Coach BR | 1.1 ppb | | | | | | | | |
| E109A sink | <1 ppb | | | | | | | | |
| E107 sink #1 | <1 ppb | | | | | | | | |
| E107 sink #2 | 5.1 ppb | | | | | | | | |
| E107 Nurse bathroom | <1 ppb | | | | | | | | |
| E108 bathroom | <1 ppb | | | | | | | | |
| Boys' BR sink #1 212B | <1 ppb | | | | | | | | |
| Boys' BR sink #2 212B | <1 ppb | | | | | | | | |
| Girls' BR sink #1 212B | <1 ppb | | | | | | | | |
| Girls' BR sink #2 212B | <1 ppb | | | | | | | | |
| Library Office | 3.8 ppb | | | | | | | | |
| 2nd fl DF tall Area 7 | 1.3 ppb | | | | | | | | |
| 2nd fl DF short Area 7 | <1 ppb | | | | | | | | |
| F200 sink #1 | <1 ppb | | | | | | | | |
| F200 sink #2 | <1 ppb | | | | | | | | |
| F202 sink #1 | 2.3 ppb | | | | | | | | |
| F202 sink #2 | 2.2 ppb | | | | | | | | |
| F211 sink #1 | <1 ppb | | | | | | | | |
| F211 sink #2 | <1 ppb | | | | | | | | |
| F213 sink #1 | 1.1 ppb | | | | | | | | |
| F213 sink #2 | 1.1 ppb | | | | | | | | |
| G200 sink #1 | 43 ppb* | shut down, wait for lead-free replacement | faucet replaced | 6.7 ppb | 12/2/16 sample | returned to service | | | |
| G200 sink #2 | 42 ppb* | shut down, wait for lead-free replacement | faucet replaced | 25 ppb* | 10/18/16 sample | | | | |
| G200 sink #3 | 49 ppb* | shut down, wait for lead-free replacement | faucet replaced | 24 ppb* | 10/18/16 sample | | | | |
| G200 sink #4 | 60 ppb* | shut down, wait for lead-free replacement | faucet replaced | 14 ppb | 10/18/16 sample | returned to service | 11 ppb | 3/6/2017 | |
| G201 sink #1 | 23 ppb* | shut down, wait for lead-free replacement | faucet replaced | 22 ppb* | 10/18/16 sample | | | | |
| G201 sink #2 | 22 ppb* | shut down, wait for lead-free replacement | faucet replaced | 5.5 ppb | 10/18/16 sample | returned to service | | | |

| | | | | | | | | |
|-------------------------------|---------|-------------------------------------------|-----------------|---------|-----------------|---------------------|-------|----------|
| G201 sink #3 | 18 ppb* | shut down, wait for lead-free replacement | faucet replaced | 27 ppb* | 10/18/16 sample | | | |
| G201 sink #4 | 32 ppb* | shut down, wait for lead-free replacement | faucet replaced | 24 ppb* | 10/18/16 sample | | | |
| G202 sink #1 | 20 ppb* | shut down, wait for lead-free replacement | faucet replaced | 13 ppb | 10/18/16 sample | returned to service | 4 ppb | 3/6/2017 |
| G202 sink #2 | 17 ppb* | shut down, wait for lead-free replacement | faucet replaced | 9.7 ppb | 10/18/16 sample | returned to service | | |
| G202 sink #3 | 18 ppb* | shut down, wait for lead-free replacement | faucet replaced | 10 ppb | 10/18/16 sample | returned to service | | |
| G202 sink #4 | 22 ppb* | shut down, wait for lead-free replacement | faucet replaced | 16 ppb* | 10/18/16 sample | | | |
| G203 Girls' BR sink #1 | 1.1 ppb | | | | | | | |
| G203 Girls' BR sink #2 | <1 ppb | | | | | | | |
| G203 Girls' BR sink #3 | 1.3 ppb | | | | | | | |
| G203 Boys' BR sink #1 | 1.5 ppb | | | | | | | |
| G203 Boys' BR sink #2 | <1 ppb | | | | | | | |
| G203 Boys' BR sink #3 | 1.6 ppb | | | | | | | |
| G203 DF tall | <1 ppb | | | | | | | |
| G203 DF short | <1 ppb | | | | | | | |
| G203 Women BR snk 1 | 1.3 ppb | | | | | | | |
| G203 Women BR snk 2 | <1 ppb | | | | | | | |
| G204 Men BR sink #1 | <1 ppb | | | | | | | |
| G204 Men BR sink #2 | <1 ppb | | | | | | | |
| G204 sink #1 | <1 ppb | | | | | | | |
| G201 DF tall | 1.3 ppb | | | | | | | |
| G201 DF short | <1 ppb | | | | | | | |
| H200 sink #1 | 1.8 ppb | | | | | | | |
| H200 sink #2 | <1 ppb | | | | | | | |
| H202 sink #1 | <1 ppb | | | | | | | |
| H202 sink #2 | <1 ppb | | | | | | | |
| H211 sink #1 | 3.2 ppb | | | | | | | |
| H211 sink #2 | <1 ppb | | | | | | | |
| H213 sink #1 | 1 ppb | | | | | | | |
| H213 sink #2 | <1 ppb | | | | | | | |
| samples taken 10/28/16 | | | | | | | | |
| Serving line sink | 2.8 ppb | | | | | | | |
| BR 120a | 1.4 ppb | | | | | | | |
| BR 120b | <1 ppb | | | | | | | |
| A101 sink #1 | 1.6 ppb | | | | | | | |
| A101 sink #2 | <1 ppb | | | | | | | |
| A103 | 7.2 ppb | | | | | | | |
| A109 | 2.3 ppb | | | | | | | |
| A112 | <1 ppb | | | | | | | |
| E109a ice machine | <1 ppb | | | | | | | |
| C100 ice machine | <1 ppb | | | | | | | |
| samples taken 12/2/16 | | | | | | | | |

| | |
|-------------------|---------|
| E109a sink | 2.7 ppb |
| E109a ice machine | <1 ppb |