

# ESM Central High School

CHS lead Testing With Updated Results from 3-19-20

ESM Central High School						
Room	Sample ID	Lead (Pb) ppb	actions taken	results received 3/19/2020		
Kitchen soup spigot	001A	3.6				
DF near lg. café L	002A	<1.0				
Df near lg. café R	003A	<1.0				
D wing DF left	004A	<1.0				
D wing DF right	005A	<1.0				
D14 prep room sink	006A	1.1				
E wing DF nr lg caf L	007A	1.1				
E wing DF nr lg caf R	008A	9.3				
E11 sink South	009A	<1.0				
E11 sink North	0010A	<1.0				
E7 sink	0011A	<1.0				
E6 sink	0012A	<1.0				
DF in hall near E22 L	0013A	<1.0				
DF in hall near E22 R	0014A	<1.0				
E22 left	0015A	<1.0				
E22 right	0016A	<1.0				
E20 sink #1	0017A	<1.0				
E20 sink #2	0018A	<1.0				
E20 sink #3	0019A	<1.0				
E20 sink #4	0020A	<1.0				
C3 SINK 3 BAY	0021A	<1.0				
DF NEAR ART ROOM	0022A	7.1				

LIBRARY	0023A	<1.0			
NURSE NS LEFT	0024A	<1.0			
NURSE NS RIGH	0025A	<1.0			
OFFICE DF RIGHT	0026A	<1.0			
OFFICE DF LEFT	0027A	<1.0			
E11 HAND SINK	0028A	<1.0			
E11 BATHROOM SINK	0029A	<1.0			
KITCHEN FOOD PREP SINK	0030A	1.9			
DF BY C3 LEFT	0031A	4.5			
DF BY C3 RIGH	0032A	5.6			
C3 PREP SINK 1L	0033A	<1.0			
C3 PREP SINK 1R	34	<1.0			
DF NEAR G19	35	<1.0			
DF NEAR G20 TALL	36	<1.0			
DF NEAR G20 SHORT	37	<1.0			
G9 SINK	38	<1.0			
G13 TEACHERS ROOM	39	<1.0			
DF NEAR G14	40	<1.0			
G14 SINK	41	<1.0			
ATRIUM BAND AREA DF	42	<1.0			
G3 BAND ROOM DF	43	<1.0			
MAIN HALLWAY DF LEFT	44	<1.0			
MAIN HALLWAY DF RIGHT	45	<1.0			
BF NEAR B13	46	9.2			
B1 FACULTYROOM	47	<1.0			
DF NEAR B36	20.0 48*		out of service, parts to be replaced	17.0* results received 3/19/2020	remains out of service
DF NEAR B43	49	<1.0			
B2 FACULTY ROOM	50	<1.0			
DF NEAR B9 SHORT	51	<1.0			

DF NEAR B9 TALL		52	<1.0			
DF NEAR WEIGHT ROOM		53	<1.0			
DF NEAR AD TALL		54	<1.0			
DF NEAR AD SHORT		55	<1.0			
DF NEAR LG GYM W		16.0 56 *		out of service, parts to be replaced	9.6 results received 3/19/2020	returned to service
KITCHEN SOUP SPIGOT RIGHT		57	10			
DF BOTTLE FILLER IN D WING		58	<1.0			
C2B BATHROOM		59	<1.0			
C2 BATHROOM		60	<1.0			
C9 SINK		61	1.9			
C10 SINK RIGHT		62	<1.0			
C10 SINK LEFT		63	<1.0			
C8 BATHROOM		64	<1.0			
C8-A SINK		65	<1.0			
C7 SINK		66	3.4			
C6 SINK LEFT		67	<1.0			
C6 SINK RIGHT		68	<1.0			
B9 SINK		69	<1.0			
WEIGHT ROOM SINK		70	<1.0			
WEIGHT ROOM ICE MACHINE		71	<1.0			
DF BOTTLE FILLER BY WEIGHT ROOM		72	<1.0			
A24 SINK		73	<1.0			
NURSES ICE MACHINE		74	<1.0			
KITCHEN ICE MACHINE		75	<1.0			