



District Office
407 Fremont Road
East Syracuse, NY 13057
Fax: 315-434-3025
www.esmschools.org

John Young
Director of Facilities

Phone: 315-434-3001
Email: johnyoung@esmschools.org

October 14, 2016

Dear East Syracuse Elementary Community:

I'd like to take this opportunity to inform you that we now have received all lead test data from samples of water that were taken from East Syracuse Elementary School prior to the Governor's September 6 signing of the law mandating such. Of 37 samples tested (see below), there currently are no readings from the building that exceed the permissible exposure limit (15 ppb) as defined by the new state law.

As of September 6, the law prescribes that additional outlets in the building be sampled and tested. Those samples were drawn in September and we expect to receive the results shortly. Once received, the results will be made available on the district's website.

Thank you for your patience throughout this process.

Sincerely,

A handwritten signature in blue ink, appearing to read "John Young", is written over a faint, light blue circular stamp or watermark.

John Young
Director of Facilities

East Syracuse Elementary

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	Lead	Actions Taken	Actions Planned
Main Office sink	<1 ppb		
8	14 ppb		
Nurse's Office	<1 ppb		
Nurse's Hall DF tall	<1 ppb		
Nurse's Hall DF shrt.	<1 ppb		
Custodial breakrm.	1.2 ppb		
Café Hallway DF tall	<1 ppb		
Café Hall DF short	<1 ppb		
Kitchen hand sink	1.3 ppb		
Kitchen sink-North	1.2 ppb		
Kitchen sink-South	1.6 ppb		
Faculty Room	<1 ppb		
Library Work Room	<1 ppb		
202 DF	<1 ppb		
204 DF	<1 ppb		
206 DF	<1 ppb		
208 DF	<1 ppb		
205 DF	<1 ppb		
210 DF	<1ppb		
211 DF	<1 ppb		
209 DF	<1 ppb		
207 DF	<1 ppb		
3 DF	<1 ppb		
2 DF	<1 ppb		
1 DF	<1 ppb		
K wing DF tall	<1 ppb		
K wing DF short	<1 ppb		
102 DF	<1 ppb		
104 DF	<1 ppb		
106 DF	<1 ppb		
108 DF	<1 ppb		
110 DF	<1 ppb		
112 DF	<1ppb		
107 DF	<1 ppb		
105 DF	<1 ppb		
103 DF	<1 ppb		
101 DF	<1 ppb		