



District Office  
407 Fremont Road  
East Syracuse, NY 13057  
Fax: 315-434-3025  
www.esmschools.org

**John Young**  
**Director of Facilities**

Phone: 315-434-3001  
Email: johnyoung@esmschools.org

---

October 14, 2016

Dear Woodland Elementary School Community:

I'd like to take this opportunity to inform you that we now have received all lead test data from samples of water that were taken from Woodland Elementary School prior to the Governor's September 6 signing of the law mandating such. Of 25 samples tested (see next page), there currently are no readings from the building that exceed the permissible exposure limit (15 ppb) as defined by the new state law.

As of September 6, the law prescribes that additional outlets in the building be sampled and tested. Those samples were drawn in September and we expect to receive the results shortly. Once received, the results will be made available on the district's website.

Thank you for your patience throughout this process.

Sincerely,

**John Young**  
**Director of Facilities**

## Woodland Elementary

\* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	Lead	Actions Taken	Actions Planned
Main Office sink	<1 ppb		
Nurse's Hallway DF	<1 ppb		
Kitchen sink #1	3.9 ppb		
Kitchen sink #2	<1 ppb		
Nurse's Office	<1 ppb		
Library breakroom	4.2 ppb		
Cust. Hallway DF	3.1 ppb		
108 Custodial sink	2.6 ppb		
DF near Rm. 133	<1 ppb		
137 sink #1	2.5 ppb		
137 sink #2	<1 ppb		
Hallway DF tall	<1 ppb		
Hallway DF short	<1 ppb		
Teachers' breakroom	4.1 ppb		
118 DF	7.9 ppb		
119 DF	5.1 ppb		
Hallway DF near 118	4.4 ppb		
120 DF	6.2 ppb		
121 DF	3.5 ppb		
122 DF	3.9 ppb		
123 DF	3.6 ppb		
124 DF	3.7 ppb		
125 DF	4.7 ppb		
127 DF	6.9 ppb		
128 DF	6.6 ppb		