

East Syracuse Elementary

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	lead	actions taken	actions planned
Main Office sink	<1 ppb		
8	14 ppb		
Nurse's Office	<1 ppb		
Nurse's Hall DF tall	<1 ppb		
Nurse's Hall DF shrt.	<1 ppb		
Custodial breakrm.	1.2 ppb		
Café Hallway DF tall	<1 ppb		
Café Hall DF short	<1 ppb		
Kitchen hand sink	1.3 ppb		
Kitchen sink-North	1.2 ppb		
Kitchen sink-South	1.6 ppb		
Faculty Room	<1 ppb		
Library Work Room	<1 ppb		
202 DF	<1 ppb		
204 DF	<1 ppb		
206 DF	<1 ppb		
208 DF	<1 ppb		
205 DF	<1 ppb		
210 DF	<1ppb		
211 DF	<1 ppb		
209 DF	<1 ppb		
207 DF	<1 ppb		
3 DF	<1 ppb		
2 DF	<1 ppb		
1 DF	<1 ppb		
K wing DF tall	<1 ppb		
K wing DF short	<1 ppb		
102 DF	<1 ppb		
104 DF	<1 ppb		
106 DF	<1 ppb		
108 DF	<1 ppb		
110 DF	<1 ppb		
112 DF	<1ppb		

107 DF	<1 ppb
105 DF	<1 ppb
103 DF	<1 ppb
101 DF	<1 ppb
samples taken 9/22/16	
Nurse bathroom	<1 ppb
Boys' gym bathroom	<1 ppb
Girls' gym bathroom	<1 ppb
Rm. 1 sink	<1ppb
Rm. 1 bathroom	<1 ppb
Rm. 2 sink	<1 ppb
Rm. 3 sink	<1 ppb
Rm. 3 bathroom	<1 ppb
101 sink	<1 ppb
101 bathroom	<1 ppb
103 sink	1.4 ppb
103 BR	<1 ppb
105 sink	<1 ppb
105 BR	<1 ppb
107 sink	<1 ppb
107 BR	<1 ppb
112 sink	<1 ppb
112 BR	2.8 ppb
110 sink	<1 ppb
110 BR	<1 ppb
108 sink	<1 ppb
108 BR	1.1 ppb
106 sink	1.2 ppb
106 BR	<1 ppb
104 sink	<1 ppb
104 BR	<1 ppb
102 sink	<1 ppb
102 BR	2.2 ppb
102 sink #1	1.1 ppb
102 sink #2	2.2 ppb
102 sink #3	1.9 ppb
102 sink #4	1.1 ppb

205 sink	<1 ppb
205 BR	2.2 ppb
207 sink	3.2 ppb
207 BR	<1 ppb
209 sink	<1 ppb
209 BR	<1 ppb
211 sink	1.2 ppb
211 BR	1.4 ppb
210 sink	<1 ppb
210 BR	<1 ppb
208 sink	1.4 ppb
208 BR	1.2 ppb
206 sink	<1 ppb
206 BR	<1 ppb
204 sink	<1 ppb
204 BR	<1 ppb
202 sink	1.1 ppb
202 BR	<1 ppb
Girls' 2nd fl. BR sink #1	<1 ppb
Girls' 2nd fl. BR sink #2	<1 ppb
Girls' 2nd fl. BR sink #3	<1 ppb
Boys' 2nd fl. BR sink#1	1.1 ppb
Boys' 2nd fl. BR sink#2	<1 ppb
Boys' 2nd fl. BR sink#3	1.1 ppb
216 sink	1.2 ppb
Cafeteria sink	<1 ppb

Fremont Elementary

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	lead	actions taken	actions planned
Kitchen sink	12 ppb		
Café DF L	2.2 ppb		
Café DF R	2.6 ppb		
Main Hall DF tall	<1 ppb		
Main Hall Dfshort	<1 ppb		
Library sink	1.3 ppb		
Main Office sink	1.2 ppb		
106 sink	<1 ppb		
110 DF	<1 ppb		
112 DF	<1 ppb		
111 DF	<1 ppb		
11 DF	12 ppb		
12 DF	6.9 ppb		
13 DF	7.4 ppb		
14 DF	4.8 ppb		
15 DF	12 ppb		
16 DF	11 ppb		
17 DF	7 ppb		
18 DF	9.7 ppb		
19 DF	13 ppb		
20 DF	3 ppb		
21 DF	8.6 ppb		
22 DF	3.9 ppb		
23 DF	3.7 ppb		
24 DF	1.8 ppb		
25 DF	4.3 ppb		
26 DF	2.3 ppb		
27 DF	3.4 ppb		
28 sink	<1 ppb		
29 sink	9.9 ppb		

Minoa Elementary		* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)	
Room	lead	actions taken	actions planned
Kitchen Women's	2.3 ppb		
Kitchen	9.5 ppb		
Café DF left	<1 ppb		
Café DF right	<1 ppb		
Hallway DF tall	<1 ppb		
Hallway DF short	<1 ppb		
Teachers' t brkrm.	2.7 ppb		
21 DF	14 ppb		
22 DF	17 ppb*	water shut off	replaced local plumbing, re-sampled and sent to lab.
23 DF	11 ppb		
24 DF	16 ppb*	water shut off	replaced local plumbing, re-sampled and sent to lab.
25 DF	15 ppb	water shut off	
26 DF	11 ppb		
27 DF	6.5 ppb		
28 DF	16 ppb*	water shut off	replaced local plumbing, re-sampled and sent to lab.
5 DF	18 ppb*	water shut off, replaced local plumbing	replaced bubbler, re-sampled and sent to lab
7 DF	18 ppb*	water shut off	replaced local plumbing, re-sampled and sent to lab.
8 DF	11 ppb		
9 DF	12 ppb		
10 DF	15 ppb	water shut off, installed in-line filter	
11 DF	11 ppb		
19 DF	9.7 ppb		
18 DF	8.3 ppb		
17 DF	12 ppb		
16 DF	46 ppb*	shut off, plumb. rem. & repl., bubbler repl, filter installed, re-sampled & re-sample & test.	
15 DF	10 ppb		
14 DF	9.9 ppb		
13 DF	46 ppb*	shut off, plumb. rem. & repl., bubbler repl, filter installed, re-sampled & re-sample & test.	
Nurse's sink faucet	<1 ppb		
Nurse's bath	3.8 ppb		
3 DF	12 ppb		
2 DF	8.5 ppb		
1 DF	1.7 ppb		
20 DF	9 ppb		

Park Hill Pre-K

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	lead	actions taken	actions planned
Kitchen sink	15 ppb	installed in-line filter	
Cafeteria DF left	1.3 ppb		
Cafeteria DF right	9.5 ppb		
305 sink	8.4 ppb		
Nurse's front sink	4.2 ppb		
Nurse's back sink	9.3 ppb		
Basement DF	<1 ppb		
6 sink	8.1 ppb		
Basement sink	5.2 ppb		
104 sink	<1 ppb		
1st Floor Hallway DF	2.1 ppb		
103A sink	1.7 ppb		
208 sink	3.4 ppb		
2nd Floor DF	5.1 ppb		
2nd fl. womens' R	3.9 ppb		
301 DF	39 ppb*	water shut off	perm. decommissioned
301 sink	3.6 ppb		
301 bathroom	12 ppb		
302 DF	22 ppb*	water shut off	perm. decommissioned
302 sink	2.6 ppb		
302 bathroom	6.9 ppb		
303 DF	15 ppb	water shut off	perm. decommissioned
303 sink	6.1 ppb		
303 bathroom	6 ppb		
304 bathroom	7.7 ppb		
305 bathroom	5 ppb		
306 DF	83 ppb*	water shut off	perm. decommissioned
306 sink	5.1 ppb		
306 bathroom	5.2 ppb		
307 sink	7.5 ppb		
307 bathroom	6.8 ppb		
308 DF	67 ppb*	water shut off	perm. decommissioned

308 sink	9.4 ppb		
308 bathroom	5.4 ppb		
309 DF	34 ppb*	water shut off	perm. decommissioned
309 sink	4.4 ppb		
309 bathroom	8.9 ppb		
1st fl. Boys' bath #1	1.8 ppb		
1st fl. Boys' bath #2	1.3 ppb		
103A bathroom	6.1 ppb		
1st fl. Girls' bath #1	4.5 ppb		
1st fl. Girls' bath #2	5.4 ppb		
2nd fl. Girls' bath #1	<1 ppb		

Woodland Elementary

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	lead	actions taken	actions planned
Main Office sink	<1 ppb		
Nurse's Hallway DF	<1 ppb		
Kitchen sink #1	3.9 ppb		
Kitchen sink #2	<1 ppb		
Nurse's Office	<1 ppb		
Library breakroom	4.2 ppb		
Cust. Hallway DF	3.1 ppb		
108 Custodial sink	2.6 ppb		
DF near Rm. 133	<1 ppb		
137 sink #1	2.5 ppb		
137 sink #2	<1 ppb		
Hallway DF tall	<1 ppb		
Hallway DF short	<1 ppb		
Teachers' breakrm.	4.1 ppb		
118 DF	7.9 ppb		
119 DF	5.1 ppb		
Hallway DF near 118	4.4 ppb		
120 DF	6.2 ppb		
121 DF	3.5 ppb		
122 DF	3.9 ppb		
123 DF	3.6 ppb		
124 DF	3.7 ppb		
125 DF	4.7 ppb		
127 DF	6.9 ppb		
128 DF	6.6 ppb		
Boys' bath near cust.	<1 ppb		
Girls' bath near cust	<1 ppb		
Nurse's bath	<1 ppb		
Rm. 128 bath	2.2 ppb		
Rm. 128 sink	6.5 ppb		
Rm. 127 bath	5.6 ppb		
Rm. 127 sink	1.1 ppb		

Rm. 126 sink	6.3 ppb
Rm. 114 fountain	4.1 ppb
Rm. 114 sink	2.3 ppb
Rm. 115 sink	1.2 ppb
Rm. 118 sink	3.4 ppb
Rm. 118 bath	<1 ppb
Rm. 119 sink	1.5 ppb
Rm. 119 bath	1.4 ppb
Rm. 121 sink	4.7 ppb
Rm. 121 bath	1.6 ppb
Rm. 120 sink	3.7 ppb
Rm. 120 bath	1ppb
Rm. 122 sink	13 ppb
Rm. 122 bath	2 ppb
Rm. 123 sink	4.5 ppb
Rm. 123 bath	1.8 ppb
Rm. 124 sink	7.7 ppb
Rm. 124 bath	2.1 ppb
Rm. 125 sink	4 ppb
Rm. 125 bath	1.2 ppb
Rm. 144 sink	1 ppb
Rm. 145 sink	<1 ppb
Rm. 142 sink	2.3 ppb
Rm. 143 sink	1.4 ppb
Rm. 154 boys' bath 1	<1 ppb
Rm. 154 boys' bath 2	<1 ppb
Rm. 154 boys' bath 3	<1 ppb
Rm. 154 boys' bath 4	<1 ppb
Rm. 139 sink	2.2 ppb
Rm. 140 sink	3.5 ppb
Rm. 136 bathroom	1.1 ppb
Rm. 135 sink	3.6 ppb
Rm. 132 sink	1.2 ppb
Rm. 149 girls' bath 1	<1 ppb
Rm. 149 girls' bath 2	<1 ppb
Rm. 149 girls' sink#3	<1 ppb
Rm. 149 girls' sink#4	<1 ppb

Rm. 133 sink	3.7 ppb
Rm. 130 sink	<1 ppb
Rmf. 131 sink	5.6 ppb
Rm. 146 sink #1	7.2 ppb
Rm. 146 sink #2	3.1 ppb

High School

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

Room	lead	actions taken	actions planned
Kitchen sink #2	2.6 ppb		
Kitchen sink-center	2.3 ppb		
Kitchen sink #1	3.8 ppb		
Kitchen soup spigot	4.5 ppb		
DF near lg. café L	<1 ppb		
Df near lg. café R	<1 ppb		
D wing DF left	<1 ppb		
D wing DF right	<1 ppb		
D11 sink	13 ppb		
D16 sink	36 ppb*	plumbing modification	re-test
D14 prep room sink	1.2 ppb		
D20 prep sink	5.5 ppb		
E wing DF nr lg caf L	13 ppb		
E wing DF nr lg caf R	11 ppb		
E11 sink South	<1 ppb		
E11 sink North	1.1 ppb		
E7 sink	<1 ppb		
E6 sink	<1 ppb		
DF in hall near E22 L	<1 ppb		
DF in hall near E22 R	<1 ppb		
E22 left	<1ppb		
E22 right	<1 ppb		
Library	2 ppb		
Nurse NS right	<1 ppb		
Nurse NS left	<1 ppb		
Staff Room KC	<1 ppb		
Office WC left 27-A	<1 ppb		
Office WC left 28-A	<1ppb		
DF near art room	8.8 ppb		
C wing teachers' bkr	1.5 ppb		
E20 sink #1	<1 ppb		
E20 sink #2	1.9 ppb		

E20 sink #3	<1 ppb
E20 sink #4	<1 ppb
C3	<1 ppb
C3 prep sink #1	<1 ppb
C3 prep sink #2	<1 ppb
DF near G19	<1 ppb
DF near G20 tall	<1 ppb
DF near G20 short	<1 ppb
G9 sink	<1 ppb
G13 (Teachers' Rm.)	1.1 ppb
DF near G14	<1 ppb
G14 sink	<1 ppb
Atrium Band area DF	<1 ppb
G3 Band Room DF	<1 ppb
Main Hallway DF L	1.7 ppb
DF near B13 R	1.5 ppb
DF near B13	4.8 ppb
B1 Faculty Room	<1 ppb
DF near B36	9.9 ppb
B2 Faculty Room	<1 ppb
DF near B43	<1 ppb
DF near B9 tall	<1 ppb
DF near B9 short	<1 ppb
DF near wgt rm tall	<1 ppb
DF near wgt rm shrt	<1 ppb
DF near AD tall	<1 ppb
DF near AD short	<1 ppb
DF near men's F7	5.9 ppb
Girls' PE Office sink	<1 ppb
Athl Trainer Off. sink	<1 ppb
Custodial Office	1.3 ppb
Concession Stand	3.4 ppb
Baseball Field	8.6 ppb

Pine Grove Middle School

* indicates that source reading exceeds 9/6/16 permissible level (15 ppb)

sample date - 10/5/2016

Room	lead	actions taken
Kitchen sink left	3.1 ppb	
Kitchen sink right	5 ppb	
Kitchen wash sink	<1 ppb	
DF near C109 short	<1 ppb	
DF near C109 tall	<1 ppb	
Rm. 105	<1 ppb	
Rm. 104	13 ppb	
100 sink #1	<1 ppb	
100 sink #2	<1 ppb	
100 sink #3	<1 ppb	
100 sink #4	<1 ppb	
100 hand sink	9.4 ppb	
101 sink	6.7 ppb	
Rm. 102	3.4 ppb	
103 bathroom	<1 ppb	
Men BR near 103 right	<1 ppb	
Men BR near 103 left	<1 ppb	
109 staff room	3.5 ppb	
DF near B103 short	<1 ppb	
DF near B103 tall	<1 ppb	
Boys' BR near B102 #1	<1 ppb	
Boys' BR near B102 #2	<1 ppb	
Boys' BR near B102 #3	1 ppb	
Women BR left	<1 ppb	
Women BR right	<1 ppb	
Girls' BR near B102 #1	<1 ppb	
Girls' BR near B102 #2	<1 ppb	
Girls' BR near B102 #3	8.9 ppb	
B102	5.9 ppb	
A113	5.8 ppb	
A100	3.2 ppb	
DF near Rm. 100 short	<1 ppb	

DF near Rm. 100 tall	<1 ppb
Girls' BR sink tall	1.2 ppb
Girls' BR sink short	1.2 ppb
Boys' BR sink tall	3.4 ppb
Boys' BR sink short	2.1 ppb
DF foyer tall	<1 ppb
DF foyer short	<1 ppb
Main Office sink	<1 ppb
Girls' BR near E102 tall	<1 ppb
Girls' BR near E102 sht	<1 ppb
Boys' BR near E102 sht	<1 ppb
Boys' BR near E102 tall	<1 ppb
DF near gym tall	<1 ppb
DF near gym short	<1 ppb
DF near gym w/bottle	<1 ppb
D103 DF	3.0 ppb
D103 sink	1.6 ppb
D102 sink	1.2 ppb
BR across from D108	<1 ppb
Girls' locker room BR	<1 ppb
Girls' LR BR sink short	<1 ppb
Girl's LR BR sink tall	<1 ppb
DF near E117 tall	<1 ppb
DF near E117 short	<1 ppb
DF bottle filler nr E117	<1 ppb
E116 Coach BR	<1 ppb
E116 Boys' LR sink #1	<1 ppb
E116 Boys' LR sink #2	<1 ppb
E116 Boys' LR sink #3	<1 ppb
E120 Coach BR	1.1 ppb
E109A sink	<1 ppb
E107 sink #1	<1 ppb
E107 sink #2	5.1 ppb
E107 Nurse bathroom	<1 ppb
E108 bathroom	<1 ppb
Boys' BR sink #1 212B	<1 ppb
Boys' BR sink #2 212B	<1 ppb

Girls' BR sink #1 212B	<1 ppb	
Girl's BR sink #2 212B	<1 ppb	
Library Office	3.8 ppb	
2nd fl DF tall Area 7	1.3 ppb	
2nd fl DF short Area 7	<1 ppb	
F200 sink #1	<1 ppb	
F200 sink #2	<1 ppb	
F202 sink #1	2.3 ppb	
F202 sink #2	2.2 ppb	
F211 sink #1	<1 ppb	
F211 sink #2	<1 ppb	
F213 sink #1	1.1 ppb	
F213 sink #2	1.1 ppb	
G200 sink #1	43 ppb*	shut down outlet, waiting for lead-free replacement faucet
G200 sink #2	42 ppb*	shut down outlet, waiting for lead-free replacement faucet
G200 sink #3	49 ppb*	shut down outlet, waiting for lead-free replacement faucet
G200 snk #4	60 ppb*	shut down outlet, waiting for lead-free replacement faucet
G201 sink #1	23 ppb*	shut down outlet, waiting for lead-free replacement faucet
G201 sink #2	22 ppb*	shut down outlet, waiting for lead-free replacement faucet
G201 sink #3	18 ppb*	shut down outlet, waiting for lead-free replacement faucet
G201 sink #4	32 ppb*	shut down outlet, waiting for lead-free replacement faucet
G202 sink #1	20 ppb*	shut down outlet, waiting for lead-free replacement faucet
G202 sink #2	17 ppb*	shut down outlet, waiting for lead-free replacement faucet
G202 sink #3	18 ppb*	shut down outlet, waiting for lead-free replacement faucet
G202 sink #4	22 ppb*	shut down outlet, waiting for lead-free replacement faucet
G203 Girls' BR sink #1	1.1 ppb	
G203 Girls' BR sink #2	<1 ppb	
G203 Girls' BR sink #3	1.3 ppb	
G203 Boys' BR sink #1	1.5 ppb	
G203 Boys' BR sink #2	<1 ppb	
G203 Boys' BR sink #3	1.6 ppb	
G203 DF tall	<1 ppb	
G203 DF short	<1 ppb	
G203 Women BR snk 1	1.3 ppb	
G203 Women BR snk 2	<1 ppb	
G204 Men BR sink #1	<1 ppb	
G204 Men BR sink #2	<1 ppb	

G204 sink #1	<1 ppb
G201 DF tall	1.3 ppb
G201 DF short	<1 ppb
H200 sink #1	1.8 ppb
H200 sink #2	<1 ppb
H202 sink #1	<1 ppb
H202 sink #2	<1 ppb
H211 sink #1	3.2 ppb
H211 sink #2	<1 ppb
H213 sink #1	1 ppb
H213 sink #2	<1 ppb